

Registration Form

**Arsenic CEU Training Course \$150.00**  
**48 HOUR RUSH ORDER PROCESSING FEE ADDITIONAL \$50.00**

Start and Finish Dates: \_\_\_\_\_  
*You will have 90 days from this date in order to complete this course*

List number of hours worked on assignment must match State Requirement. \_\_\_\_\_

Name \_\_\_\_\_ Signature \_\_\_\_\_  
*I have read and understood the disclaimer notice on page 2. Digitally sign XXX*

Address \_\_\_\_\_

City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Email \_\_\_\_\_ Fax (\_\_\_\_) \_\_\_\_\_

Phone:  
Home (\_\_\_\_) \_\_\_\_\_ Work (\_\_\_\_) \_\_\_\_\_

Operator ID # \_\_\_\_\_ Exp. Date \_\_\_\_\_

Class/Grade \_\_\_\_\_

**Please circle/check which certification you are applying the course CEU's.**

Pretreatment \_\_\_ Collection \_\_\_ Wastewater Treatment \_\_\_

Other \_\_\_\_\_

Technical Learning College TLC PO Box 3060, Chino Valley, AZ 86323  
Toll Free (866) 557-1746 Fax (928) 272-0747 [info@tlch2o.com](mailto:info@tlch2o.com)

If you've paid on the Internet, please write your Customer# \_\_\_\_\_

Please invoice me, my PO# \_\_\_\_\_

**We will stop mailing the certificate of completion so we need either your fax number or e-mail address. We will e-mail the certificate to you, if no e-mail address; we will fax it to you.**

## **DISCLAIMER NOTICE**

I understand that it is my responsibility to ensure that this CEU course is either approved or accepted in my State for CEU credit. I understand State laws and rules change on a frequent basis and I believe this course is currently accepted in my State for CEU or contact hour credit, if it is not, I will not hold Technical Learning College responsible. I fully understand that this type of study program deals with dangerous, changing conditions and various laws and that I will not hold Technical Learning College, Technical Learning Consultants, Inc. (TLC) liable in any fashion for any errors, omissions, advice, suggestions or neglect contained in this CEU education training course or for any violation or injury, death, neglect, damage or loss of your license or certification caused in any fashion by this CEU education training or course material suggestion or error or my lack of submitting paperwork. It is my responsibility to call or contact TLC if I need help or assistance and double-check to ensure my registration page and assignment has been received and graded. It is my responsibility to ensure all information is correct and to abide with all rules and regulations.

**State Approval Listing Link**, check to see if your State accepts or has pre-approved this course. Not all States are listed. Not all courses are listed. If the course is not accepted for CEU credit, we will give you the course free if you ask your State to accept it for credit.

**Professional Engineers;** Most states will accept our courses for credit but we do not officially list the States or Agencies. Please check your State for approval.

## **State Approval Listing URL...**

<http://www.abctlc.com/downloads/PDF/CEU%20State%20Approvals.pdf>

*You can obtain a printed version of the course manual from TLC for an additional \$99.95 plus shipping charges.*

## **AFFIDAVIT OF EXAM COMPLETION**

I affirm that I personally completed the entire text of the course. I also affirm that I completed the exam without assistance from any outside source. I understand that it is my responsibility to file or maintain my certificate of completion as required by the state or by the designation organization.

## **Grading Information**

In order to maintain the integrity of our courses we do not distribute test scores, percentages or questions missed. Our exams are based upon pass/fail criteria with the benchmark for successful completion set at 70%. Once you pass the exam, your record will reflect a successful completion and a certificate will be issued to you.

For security purposes, please fax or e-mail a copy of your driver's license and always call us to confirm we've received your assignment and to confirm your identity.

# Arsenic Answer Key

Name \_\_\_\_\_ Phone \_\_\_\_\_

*Did you check with your State agency to ensure this course is accepted for credit?*

*Method of Course acceptance confirmation. Please fill this section*

Website \_\_\_ Telephone Call \_\_\_ Email \_\_\_ Spoke to \_\_\_\_\_

Did you receive the approval number, if applicable? \_\_\_\_\_

What is the course approval number, if applicable? \_\_\_\_\_

*You are responsible to ensure that TLC receives the Assignment and Registration Key. Please call us to ensure that we received it.*

You can also fill this assignment out electronically in Adobe Acrobat DC

***Please write down any questions that cannot be found or has problems***

***Please circle, underline, bold or X only one correct answer***

***A felt tipped pen works best.***

- |             |             |             |             |
|-------------|-------------|-------------|-------------|
| 1. A B C D  | 17. A B     | 33. A B C D | 49. A B C D |
| 2. A B C D  | 18. A B C D | 34. A B C D | 50. A B C D |
| 3. A B C D  | 19. A B C D | 35. A B C D | 51. A B C D |
| 4. A B C D  | 20. A B C D | 36. A B C D | 52. A B C D |
| 5. A B C D  | 21. A B C D | 37. A B C D | 53. A B C D |
| 6. A B C D  | 22. A B     | 38. A B C D | 54. A B C D |
| 7. A B C D  | 23. A B C D | 39. A B C D | 55. A B C D |
| 8. A B C D  | 24. A B C D | 40. A B     | 56. A B C D |
| 9. A B C D  | 25. A B C D | 41. A B C D | 57. A B C D |
| 10. A B C D | 26. A B C D | 42. A B C D | 58. A B C D |
| 11. A B C D | 27. A B C D | 43. A B C D | 59. A B C D |
| 12. A B C D | 28. A B C D | 44. A B C D | 60. A B     |
| 13. A B C D | 29. A B C D | 45. A B C D | 61. A B C D |
| 14. A B C D | 30. A B C D | 46. A B C D | 62. A B C D |
| 15. A B C D | 31. A B C D | 47. A B C D | 63. A B C D |
| 16. A B C D | 32. A B C D | 48. A B C D | 64. A B C D |

- |             |              |              |              |
|-------------|--------------|--------------|--------------|
| 65. A B C D | 96. A B C D  | 127. A B C D | 158. A B C D |
| 66. A B C D | 97. A B C D  | 128. A B C D | 159. A B C D |
| 67. A B C D | 98. A B C D  | 129. A B C D | 160. A B     |
| 68. A B C D | 99. A B C D  | 130. A B C D | 161. A B C D |
| 69. A B C D | 100. A B C D | 131. A B C D | 162. A B C D |
| 70. A B C D | 101. A B C D | 132. A B C D | 163. A B C D |
| 71. A B C D | 102. A B C D | 133. A B C D | 164. A B C D |
| 72. A B C D | 103. A B C D | 134. A B C D | 165. A B C D |
| 73. A B C D | 104. A B C D | 135. A B C D | 166. A B C D |
| 74. A B C D | 105. A B C D | 136. A B C D | 167. A B C D |
| 75. A B C D | 106. A B C D | 137. A B C D | 168. A B C D |
| 76. A B C D | 107. A B C D | 138. A B C D | 169. A B C D |
| 77. A B C D | 108. A B C D | 139. A B C D | 170. A B C D |
| 78. A B C D | 109. A B C D | 140. A B C D | 171. A B C D |
| 79. A B C D | 110. A B C D | 141. A B C D | 172. A B C D |
| 80. A B C D | 111. A B C D | 142. A B C D | 173. A B C D |
| 81. A B C D | 112. A B C D | 143. A B C D | 174. A B C D |
| 82. A B C D | 113. A B C D | 144. A B     | 175. A B C D |
| 83. A B C D | 114. A B     | 145. A B C D | 176. A B C D |
| 84. A B C D | 115. A B C D | 146. A B C D | 177. A B C D |
| 85. A B C D | 116. A B C D | 147. A B     | 178. A B C D |
| 86. A B C D | 117. A B C D | 148. A B C D | 179. A B     |
| 87. A B C D | 118. A B C D | 149. A B     | 180. A B C D |
| 88. A B C D | 119. A B     | 150. A B C D | 181. A B C D |
| 89. A B C D | 120. A B C D | 151. A B C D | 182. A B C D |
| 90. A B C D | 121. A B C D | 152. A B     | 183. A B C D |
| 91. A B C D | 122. A B C D | 153. A B C D | 184. A B C D |
| 92. A B C D | 123. A B C D | 154. A B C D | 185. A B C D |
| 93. A B C D | 124. A B     | 155. A B C D | 186. A B C D |
| 94. A B C D | 125. A B     | 156. A B C D | 187. A B C D |
| 95. A B C D | 126. A B C D | 157. A B C D | 188. A B C D |

- |              |              |              |              |
|--------------|--------------|--------------|--------------|
| 189. A B C D | 217. A B C D | 245. A B C D | 273. A B C D |
| 190. A B C D | 218. A B C D | 246. A B C D | 274. A B C D |
| 191. A B C D | 219. A B C D | 247. A B C D | 275. A B C D |
| 192. A B C D | 220. A B C D | 248. A B C D | 276. A B C D |
| 193. A B C D | 221. A B C D | 249. A B C D | 277. A B C D |
| 194. A B C D | 222. A B C D | 250. A B C D | 278. A B C D |
| 195. A B C D | 223. A B C D | 251. A B C D | 279. A B C D |
| 196. A B C D | 224. A B C D | 252. A B C D | 280. A B C D |
| 197. A B C D | 225. A B C D | 253. A B C D | 281. A B C D |
| 198. A B C D | 226. A B C D | 254. A B C D | 282. A B C D |
| 199. A B C D | 227. A B C D | 255. A B C D | 283. A B C D |
| 200. A B C D | 228. A B C D | 256. A B C D | 284. A B C D |
| 201. A B C D | 229. A B C D | 257. A B C D | 285. A B C D |
| 202. A B C D | 230. A B C D | 258. A B C D | 286. A B C D |
| 203. A B C D | 231. A B C D | 259. A B C D | 287. A B C D |
| 204. A B C D | 232. A B C D | 260. A B C D | 288. A B C D |
| 205. A B C D | 233. A B C D | 261. A B C D | 289. A B C D |
| 206. A B C D | 234. A B C D | 262. A B C D | 290. A B C D |
| 207. A B C D | 235. A B C D | 263. A B C D | 291. A B C D |
| 208. A B C D | 236. A B C D | 264. A B C D | 292. A B C D |
| 209. A B     | 237. A B C D | 265. A B C D | 293. A B C D |
| 210. A B C D | 238. A B C D | 266. A B C D | 294. A B C D |
| 211. A B C D | 239. A B C D | 267. A B C D | 295. A B C D |
| 212. A B C D | 240. A B C D | 268. A B C D | 296. A B C D |
| 213. A B C D | 241. A B C D | 269. A B C D | 297. A B C D |
| 214. A B C D | 242. A B C D | 270. A B C D | 298. A B C D |
| 215. A B C D | 243. A B C D | 271. A B C D | 299. A B C D |
| 216. A B C D | 244. A B C D | 272. A B C D | 300. A B C D |

*This course contains general EPA's SDWA and CWA federal rule requirements. Please be aware that each state implements water / wastewater / safety / environmental / building regulations that may be more stringent than EPA's regulations. Check with your state environmental/health agency for more information. These rules change frequently and are often difficult to interpret and follow. Be careful to not be in non-compliance and do not follow this course for proper compliance.*

**Please e-mail or fax this survey along with your final exam**

## **ARSENIC CEU TRAINING COURSE**

### **CUSTOMER SERVICE RESPONSE CARD**

NAME: \_\_\_\_\_

E-MAIL \_\_\_\_\_ PHONE \_\_\_\_\_

**PLEASE COMPLETE THIS FORM BY CIRCLING THE NUMBER OF THE APPROPRIATE ANSWER IN THE AREA BELOW.**

1. Please rate the difficulty of your course.

Very Easy 0 1 2 3 4 5 Very Difficult

2. Please rate the difficulty of the testing process.

Very Easy 0 1 2 3 4 5 Very Difficult

3. Please rate the subject matter on the exam to your actual field or work.

Very Similar 0 1 2 3 4 5 Very Different

4. How did you hear about this Course? \_\_\_\_\_

5. How would you improve the course?

\_\_\_\_\_

How about the price of the course?

Poor \_\_\_\_\_ Fair \_\_\_\_\_ Average \_\_\_\_\_ Good \_\_\_\_\_ Great \_\_\_\_\_

How was your customer service?

Poor \_\_\_\_\_ Fair \_\_\_\_\_ Average \_\_\_\_\_ Good \_\_\_\_\_ Great \_\_\_\_\_

Any other concerns or comments.

\_\_\_\_\_  
\_\_\_\_\_





# Arsenic CEU Training Course Assignment

You will have 90 days from the start of this assignment to have successfully completed and submit this assignment back to TLC.

If you need course assistance, please call us at (928) 468-0665 or go to the Assistance Page on TLC's website. You can find online assistance for this course on the in the Search function on Adobe Acrobat PDF to help find the answers.

## Arsenic Introduction

### Metalloid

1. Arsenic is a chemical element with symbol \_\_\_\_\_ and the atomic number is \_\_\_\_\_.  
A. AR – 35    C. As - 33  
B. AS – 13    D. None of the above
2. Arsenic happens in many minerals, usually in conjunction with \_\_\_\_\_, and also as a pure elemental crystal. It was first documented by Albertus Magnus in 1250.  
A. Sulfur and metals                      C. Alloys of copper  
B. Inorganics                                D. None of the above
3. Arsenic is a metalloid and can exist in \_\_\_\_\_, although only the gray form has important use in industry.  
A. Various allotropes                      C. Inorganic forms  
B. The trioxide                                D. None of the above
4. In 1974, Congress passed the Safe Drinking Water Act. This law requires EPA to determine the level of contaminants in drinking water at which no \_\_\_\_\_ are likely to occur.  
A. Adverse health effects                C. These non-enforceable health goals  
B. MCLG                                        D. None of the above
5. Which of the following is based solely on possible health risks and exposure over a lifetime with an adequate margin of safety, are called maximum contaminant level goals?  
A. Adverse health effects                C. These non-enforceable health goals  
B. MCLG                                        D. None of the above
6. Which of the following are any physical, chemical, biological or radiological substances or matter in water?  
A. Contaminants                              C. Pollutants  
B. Chemicals                                 D. None of the above
7. Which of the following for arsenic is zero?  
A. Standard    C. Safe Drinking Water Act limit  
B. MCLG        D. None of the above
8. Based on the MCLG, EPA has set an enforceable regulation for arsenic, called a maximum contaminant level, at?  
A. Zero    C. 0.010 mg/L or 10 ppb  
B. 0.050 mg/L or 1.0 ppb                D. None of the above

9. Which of the following are set as close to the health goals as possible, considering cost, benefits and the ability of public water systems to detect and remove contaminants?
- A. MCLs                      C. ppb  
B. MCLG                      D. None of the above
10. The main uses of \_\_\_\_\_ is for strengthening alloys of copper and especially lead.
- A. Alloys of copper                      C. Metallic arsenic  
B. Inorganic arsenic                      D. None of the above
11. Arsenic is a common n-type dopant in semiconductor electronic devices, and the optoelectronic compound of this missing term is the most common semiconductor in use after doped silicon.
- A. Gallium arsenide                      C. Trioxide  
B. Arsenic alloys                      D. None of the above
12. Arsenic and its compounds, especially of this missing term are used in the production of pesticides, herbicides, and insecticides. These applications are declining, however.
- A. Gallium arsenide                      C. Trioxide  
B. Arsenic alloys                      D. None of the above
13. Which of the following represents a groundwater problem that affects millions of people across the world?
- A. The trioxide contamination                      C. Hydrogen contamination  
B. Arsenic contamination                      D. None of the above
14. Arsenic, a naturally occurring element, is found throughout the environment; for most people?
- A. A naturally occurring element                      C. Food is the major source of exposure  
B. Inorganic arsenic                      D. None of the above
15. Acute high-level inhalation exposure to arsenic dust or fumes has resulted in gastrointestinal effects; central and peripheral nervous system disorders have occurred in workers acutely exposed to?
- A. The Metalloid                      C. Inorganic arsenic  
B. Arsenic and hydrogen                      D. None of the above
16. Chronic (long-term) inhalation exposure to this missing term in humans is associated with irritation of the skin and mucous membranes.
- A. The Metalloid                      C. Inorganic arsenic  
B. Arsenic and hydrogen                      D. None of the above
17. Chronic oral exposure has resulted in gastrointestinal effects, anemia, peripheral neuropathy, skin lesions, hyperpigmentation, and liver or kidney damage in humans
- A. True                      B. False
18. EPA has classified inorganic arsenic as a?
- A. Group A, human carcinogen                      C. Group A, Exposures  
B. Risk factor for type 2 diabetes                      D. None of the above

**Arsine**

19. EPA has not classified arsine for?  
A. Body weight basis                      C. Exposures and risks for the fetus  
B. Carcinogenicity                         D. None of the above
20. Which of the following require public water systems to monitor for arsenic at the entry point to the distribution system?  
A. Drinking water regulations            C. MCLG  
B. MCLs                                        D. None of the above
21. The Operator may want to test their distribution system water for arsenic to be sure that the water being delivered has arsenic levels below the?  
A. MCLG            C. Action level  
B. MCL             D. None of the above
22. If you decide to monitor your distribution system, consider testing for arsenic at locations where the settling and accumulation of iron solids or pipe scales are likely (i.e., areas with cast iron pipe, ductile iron pipe, or galvanized iron pipe).  
A. True            B. False
23. A change in the taste, odor or appearance of the water at \_\_\_\_\_ may be the first indication of an arsenic problem.  
A. Pipe scales                                C. Customers' taps  
B. The distribution system                D. None of the above
24. Which of the following to consider when monitoring, depending on your arsenic treatment technology, include iron, pH, manganese, alkalinity, and aluminum?  
A. Arsenic acid in water                    C. Some water quality parameters  
B. Readily soluble in water                D. None of the above
25. The current drinking water standard or Maximum Contaminant Level set by the U.S. Environmental Protection Agency is 0.010 mg/L or parts per million, this is equivalent to?  
A. 50 ppb to 10 ppb                        C. 10 ug/L (micrograms per liter) or 10 ppb  
B. 0.010 mg/L or 100 ppb                D. None of the above
26. In 2001, the U.S. Environmental Protection Agency (EPA) reduced the regulatory MCL from \_\_\_\_\_ on the basis on bladder and lung cancer risks.  
A. 50 ppb to 10 ppb                        C. 10 ug/L (micrograms per liter) or 10 ppb  
B. 0.010 mg/L or 100 ppb                D. None of the above
27. Long term exposure to drinking water containing arsenic at levels higher than this term increases the chances of getting cancer, while for lower arsenic water levels the chances are less.  
A. 50 ppb to 10 ppb                        C. 10 ug/L (micrograms per liter) or 10 ppb  
B. 10 ppb                                        D. None of the above

28. If your water has arsenic levels above this term, you should obtain drinking water from another source or install a home treatment device.

- A. 50 ppb to 10 ppb    C. 10 ug/L (micrograms per liter) or 10 ppb  
B. 10 ppb                      D. None of the above

29. Concentrations above this term will increase the risk of long-term or chronic health problems, the higher the level and length of exposure.

- A. 50 ppb to 10 ppb    C. 10 ug/L (micrograms per liter) or 10 ppb  
B. 10 ppb                      D. None of the above

30. Children are at greater risk (to any agent in water) because of their greater water consumption on a per unit?

- A. Body weight basis                      C. Exposures and risks  
B. Risk factor for type 2 diabetes    D. None of the above

31. Pregnant women may wish to reduce \_\_\_\_\_ because arsenic has been found at low levels in mother's milk and will cross the placenta, increasing exposures and risks for the fetus.

- A. Arsenic exposures                      C. Exposures and risks for the fetus  
B. Risk factor                              D. None of the above

32. If your water has arsenic levels above this term, you should immediately stop drinking the water until you can either obtain water from another source or install and maintain treatment.

- A. 10 ppb                      C. 0.10 mg/L or 100 ppb  
B. 200 ppb                      D. None of the above

### Physical Characteristics

33. The three most common arsenic allotropes are metallic gray, yellow and \_\_\_\_\_, with gray being the most common.

- A. Black arsenic                      C. Phosphorus acid  
B. Arsenates                              D. None of the above

34. Which of the following is brittle and has a relatively low Mohs hardness of 3.5?

- A. Arsenates                              C. Gray arsenic  
B. Solid yellow arsenic              D. None of the above

35. Nearest and next-nearest neighbors form this term, with the three atoms in the same double-layer being slightly closer than the three atoms in the next.

- A. Arsenic acid                              C. A distorted octahedral complex  
B. Alloy-like intermetallic compounds    D. None of the above

36. Solid yellow arsenic is produced by rapid cooling of arsenic vapor,  $As_4$ . It is rapidly transformed into this term by light.

- A. Arsenates                              C. Gray arsenic  
B. Solid yellow arsenic              D. None of the above

37. Which of the following is similar in structure to red phosphorus?

- A. Synthetic arsenates              C. Alloy-like intermetallic compounds  
B. Black arsenic                              D. None of the above



47. Synthetic arsenates include this term, calcium arsenate, and lead hydrogen arsenate.  
 A. Gray arsenic                      C. Paris Green  
 B. White arsenic                      D. None of the above
48. The protonation steps between the arsenate and arsenic acid are similar to those between?  
 A. Phosphate and phosphoric acid    C. Sulfur compounds  
 B. Arsenous acid                      D. None of the above
49. Unlike phosphorus acid, this term is genuinely tribasic, with the formula  $\text{As}(\text{OH})_3$ .  
 A. Phosphate and phosphoric acid    C. Sulfur compounds  
 B. Arsenous acid                      D. None of the above
50. A broad variety of this term of arsenic are known.  
 A. Phosphate and phosphoric acid    C. Sulfur compounds  
 B. Arsenous acid                      D. None of the above
51. In which of the following, arsenic has a formal oxidation state of +2 in  $\text{As}_4\text{S}_4$ , which features As-As bonds so that the total covalency of As is still three?  
 A.  $\text{As}_4\text{S}_{10}$                       C. Phosphorus acid  
 B.  $\text{As}_2\text{S}_{12}$                       D. None of the above

### Alloys

52. Arsenic is used as the group 5 element in the III-V semiconductors \_\_\_\_\_, indium arsenide, and aluminum arsenide.  
 A. Cadmium arsenide                      C. Gallium arsenide  
 B. Arsenic alloys                      D. None of the above
53. Other arsenic alloys include the II-IV semiconductor?  
 A. Cadmium arsenide                      C. Gallium arsenide  
 B. Arsenic alloys                      D. None of the above

### Health Hazard Information

54. While arsenic levels may fluctuate over time, what is most significant from the standpoint of \_\_\_\_\_ is long-term exposure.  
 A. Pregnancy                      C. Exposures and risks for the fetus  
 B. Cancer risk                      D. None of the above
55. For water systems in the 25 states that reported arsenic data to the EPA, we have calculated \_\_\_\_\_ estimates of average long-term levels: one is a very conservative estimate, the other our best estimate, based on what we believe to be the most reasonable analytical techniques.  
 A. 10                      C. 5  
 B. 2                      D. None of the above

### **Arsenic Diabetes**

56. New research findings from the National Health and Nutrition Examination Survey suggest that exposure to levels of arsenic commonly found in drinking water may be a risk factor for?

- A. Body weight
- B. Type 2 diabetes
- C. Exposures and risks for the fetus
- D. None of the above

57. The findings suggest that millions of Americans may be at increased \_\_\_\_\_ based on the level of arsenic in their drinking water.

- A. Risk factor for type 2 diabetes
- B. Prevalence of type 2 diabetes
- C. Cancer risk is long-term exposure
- D. None of the above

58. Data on the nearly 800 participants in the study for which urinary arsenic concentrations were available, indicated that urine levels of arsenic were significantly associated with the?

- A. Body weight basis
- B. Prevalence of type 2 diabetes
- C. Exposures and risks for the fetus
- D. None of the above

59. Which of the following in drinking water at concentrations higher than 100 parts per million has been linked to type 2 diabetes in studies that took place in Taiwan, Mexico, and Bangladesh?

- A. Arsenic
- B. Arsenic alloys
- C. Inorganic arsenic
- D. None of the above

60. Animal studies have shown that arsenic affects the production of glucose, insulin secretion and can cause insulin resistance.

- A. True
- B. False

61. The researchers estimate that about 13 million Americans live in areas where public water systems exceed the?

- A. EPA standard
- B. Action level
- C. MCLG
- D. None of the above

62. The current findings reinforce the need to evaluate the role of arsenic in diabetes development in prospective epidemiologic studies conducted in populations exposed to a wide range of levels of?

- A. Arsenic
- B. Arsenic alloys
- C. Organic arsenic
- D. None of the above

### **Acute Effects:**

#### **Inorganic Arsenic**

63. Which of the following of workers to high levels of arsenic dusts or fumes has resulted in gastrointestinal effects?

- A. Acute exposure
- B. Acute inhalation exposure
- C. Acute arsine exposure
- D. None of the above

64. Acute oral exposure to inorganic arsenic, at doses of approximately 600 micrograms per kilogram body weight per day or higher in humans, has resulted in death.

- A. 60
- B. 6,000
- C. 600
- D. None of the above

65. Which of the following type of exposure to lower levels of inorganic arsenic has resulted in effects on the gastrointestinal tract, central nervous system, cardiovascular system, liver, kidney, and blood.

- A. Acute
- B. Oral
- C. Acute oral
- D. None of the above

66. Acute animal tests in rats and mice have shown inorganic arsenic to have?

- A. Acute exposure
- B. Acute inhalation exposure
- C. Moderate to high acute toxicity
- D. None of the above

### **Arsine**

67. Acute inhalation exposure to arsine by humans has resulted in death; it has been reported that a half-hour exposure to 25 to 50 parts per million can be lethal?

- A. 15 to 30
- B. 25 to 50
- C. 25 to 70
- D. None of the above

68. The major effects from \_\_\_\_\_ in humans include headaches, vomiting, abdominal pains, hemolytic anemia, hemoglobinuria, and jaundice; these effects can lead to kidney failure.

- A. Acute animal tests
- B. Acute inhalation exposure
- C. Acute arsine exposure
- D. None of the above

69. Arsine has been shown to have extreme acute toxicity from?

- A. Acute exposure
- B. Acute inhalation exposure
- C. Acute animal tests
- D. None of the above

### **Chronic Effects (Non-cancer):**

#### **Inorganic Arsenic**

70. Which of the following to inorganic arsenic in humans is associated with irritation of the skin and mucous membranes?

- A. Chronic oral exposure
- B. Oral animal studies
- C. Chronic inhalation exposure
- D. None of the above

71. Which of the following to inorganic arsenic in humans has resulted in gastrointestinal effects, anemia, peripheral neuropathy, skin lesions, hyperpigmentation, gangrene of the extremities, vascular lesions, and liver or kidney damage?

- A. Chronic oral exposure
- B. Chronic inhalation exposure
- C. Ingested inorganic arsenic
- D. None of the above

72. No \_\_\_\_\_ studies have been performed in animals for any inorganic arsenic compound.

- A. Human
- B. Oral animal
- C. Chronic inhalation exposure
- D. None of the above

73. Some studies have suggested that this term is an essential dietary nutrient in goats, chicks, and rats.

- A. Arsenic
- B. Arsenic alloys
- C. Inorganic arsenic
- D. None of the above



**Reproductive/Developmental Effects:  
Inorganic Arsenic**

74. Several studies have suggested that women who work in, or live near, metal smelters may have higher than normal spontaneous abortion rates, and their children may exhibit lower than normal birth weights, these studies are limited because they were designed to evaluate the effects of smelter pollutants in general, and are not specific for?

- A. Organic arsenic
- B. Arsenic alloys
- C. Inorganic arsenic
- D. None of the above

75. Ingested \_\_\_\_\_ can cross the placenta in humans, exposing the fetus to the chemical.

- A. Organic arsenic
- B. Arsenic alloys
- C. Inorganic arsenic
- D. None of the above

76. Oral animal studies have reported this term at very high doses to be fetotoxic and to cause birth defects.

- A. Organic arsenic
- B. Arsenate
- C. Inorganic arsenic
- D. None of the above

**Arsine**

77. Human studies have indicated higher than expected spontaneous abortion rates in women in the microelectronics industry who were exposed to arsine. However, these studies have several limitations, including small sample size and exposure to this missing term in addition to arsine.

- A. Arsine
- B. Arsenic alloys
- C. Arsenate
- D. None of the above

**Cancer Risk: Inorganic arsenic**

78. Which of the following studies have reported inorganic arsenic exposure to be strongly associated with lung cancer?

- A. Chronic oral exposure
- B. Oral animal
- C. Human, inhalation
- D. None of the above

79. Which of the following in humans has been associated with an increased risk of nonmelanoma skin cancer and also to an increased risk of bladder, liver, and lung cancer?

- A. Chronic oral exposure
- B. Acute exposure
- C. Ingested inorganic arsenic
- D. None of the above

80. Which of the following have not associated inorganic arsenic exposure via the oral route with cancer, and no cancer inhalation studies have been performed in animals for inorganic arsenic?

- A. Acute animal tests
- B. Acute inhalation exposure
- C. Animal studies
- D. None of the above

81. EPA has classified this term as a Group A, human carcinogen.

- A. Arsine
- B. Arsenic alloys
- C. Inorganic arsenic
- D. None of the above

## **Arsenic Applications**

### **Agricultural**

82. The toxicity of arsenic to insects, bacteria and fungi led to its use as a wood preservative. In the 1950s a process of treating wood with \_\_\_\_\_ was invented, and for decades this treatment was the most extensive industrial use of arsenic.

- A. Chromated copper arsenate
- B. Arsenic alloys
- C. Organic arsenic
- D. None of the above

83. Which of the following was a common insecticide on fruit trees, but contact with the compound sometimes resulted in brain damage among those working the sprayers?

- A. Organic arsenic
- B. Arsenic alloys
- C. Lead hydrogen arsenate
- D. None of the above

84. Which of the following and disodium methyl arsenate (DSMA) – less toxic organic forms of arsenic – have replaced lead arsenate in agriculture?

- A. Arsphenamine
- B. Monosodium methyl arsenate (MSMA)
- C. Fowler's solution
- D. None of the above

85. Which of the following is still added to animal food, in particular in the US as a method of disease prevention and growth stimulation?

- A. Roxarsone
- B. Arsenic
- C. Fowler's solution
- D. None of the above

86. The Poison-Free Poultry Act of 2009 proposes to ban the use of \_\_\_\_\_ in industrial swine and poultry production.

- A. Roxarsone
- B. Fowler's solution
- C. Less toxic organic forms of arsenic
- D. None of the above

87. Alpharma, a subsidiary of Pfizer Inc., which produces \_\_\_\_\_ and has voluntarily suspended sales of the drug in response to studies showing elevated levels of arsenic in treated chickens.

- A. Roxarsone
- B. Fowler's solution
- C. Less toxic organic forms of arsenic
- D. None of the above

### **Medical Use**

88. During the 18th, 19th, and 20th centuries, a number of arsenic compounds have been used as medicines, including?

- A. Arsphenamine
- B. Arsenic
- C. Fowler's solution
- D. None of the above

89. Arsphenamine as well as this term was indicated for syphilis and trypanosomiasis, but has been superseded by modern antibiotics.

- A. Arsphenamine
- B. Neosalvarsan
- C. Fowler's solution
- D. None of the above

90. Which of the following has been used in a variety of ways over the past 500 years, but most commonly in the treatment of cancer?

- A. Arsenic trioxide
- B. Arsenates
- C. Phosphorus acid
- D. None of the above

91. Which of the following was used as in treatment of psoriasis?

- A. Arsphenamine
- C. Fowler's solution
- B. Arsenic
- D. None of the above

92. Which of the following act as stimulants, and were once popular in small doses as medicine by people in the mid-18th century?

- A. Roxarsone
- C. Soluble arsenic compounds
- B. Arsphenamine
- D. None of the above

### Alloys

93. Which of the following is for alloying with lead?

- A. Metallic arsenic
- C. Phosphorus acid
- B. Arsenic alloys
- D. None of the above

94. Which of the following is an important semiconductor material, used in integrated circuits?

- A. Arsenic
- C. Gallium arsenide
- B. Arsenic alloys
- D. None of the above

95. Circuits made from this term are much faster than those made in silicon.

- A. GaAs
- C. Phosphorus acid
- B. Arsenates
- D. None of the above

### Bacteria

96. Under oxidative environmental conditions some bacteria use arsenite, which is oxidized to this term as fuel for their metabolism.

- A. Arsphenamine
- C. Fowler's solution
- B. Arsenate
- D. None of the above

97. The enzymes involved are known as?

- A. Iron media
- C. Arsenate reductases (Arr)
- B. Arsenic-rich particles
- D. None of the above

### Arsenic Control Measures Can Affect Finished Water Quality

98. Some systems may need to adjust their finished water quality to address new concerns about?

- A. Iron media
- C. Corrosion
- B. Water chemistry
- D. None of the above

99. Which of the following due to using new sources, blending different source waters, or installing arsenic treatment are some of the factors that can affect distribution system water quality?

- A. Water chemistry
- C. Arsenic-rich particles
- B. Arsenic levels
- D. None of the above

100. In some cases, this may cause an increase in \_\_\_\_\_ in the distribution system or create simultaneous compliance issues with other drinking water regulations.

- A. Iron media
- C. Arsenate reductases (Arr)
- B. Arsenic levels
- D. None of the above

101. Water systems may also find deposits of this term in their storage tanks or at locations in their distribution system with low flows.

- A. Water chemistry
- B. Arsenic levels
- C. Arsenic-rich particles
- D. None of the above

102. This situation occurs primarily when this term used in treatment are released into the distribution system.

- A. Iron media
- B. Arsenic-rich particles
- C. Arsenate reductases (Arr)
- D. None of the above

### **Is Arsenic in your Storage Tank?**

### **Is Your Ground Water System Installing Disinfection for Pathogen Control?**

103. Water systems that disinfect their water should be aware of the possibility of an increase in arsenic concentrations in their distribution system, particularly if the water contains high concentrations of dissolved?

- A. Dissolved iron
- B. Arsenic alloys
- C. Aluminum arsenide
- D. None of the above

104. When chlorinated, the dissolved iron forms particles on which arsenic can accumulate. As a result, high arsenic concentrations may occur in distribution system water even if arsenic concentrations in the raw water are below the?

- A. MCL
- B. MCLG
- C. 0.010 mg/L or 10 ppb
- D. None of the above

105. This happened to a small community water system in the Midwest that began chlorinating water from a series of wells that had raw water arsenic levels between 0.003 and 0.008 mg/L and iron concentrations up to?

- A. 10 ppb
- B. 0.4 mg/L
- C. 0.10 mg/L or 100 ppb
- D. None of the above

106. Soon after chlorination begins, the system received intermittent \_\_\_\_\_ complaint from its customers with increasing frequency across the distribution system.

- A. Colored-water
- B. Arsenic exposure
- C. Toxic waste
- D. None of the above

107. Which of the following collected from several representative locations throughout the service area had a reddish-brown color and contained particles?

- A. Arsenic poisoning
- B. Samples
- C. Source water
- D. None of the above

108. A metals analysis showed high levels of copper and iron oxides in the finished water, along with arsenic concentrations approaching?

- A. 50 ppb to 10 ppb
- B. 0.4 mg/L
- C. 5 mg/L
- D. None of the above

109. Doctors and health care professionals were notified of the situation and instructed to watch for signs of?

- A. Chronic oral exposure
- B. Arsenic poisoning
- C. Chronic inhalation exposure
- D. None of the above

110. Researchers found that chlorinating the water caused the formation of?  
A. Ferri-hydroxide solids                      C. Toxic waste disposal problem  
B. Organic compound arsenobetaine        D. None of the above

### **Biomethylation**

111. Inorganic arsenic and its compounds, upon entering the food chain, are progressively metabolized through?  
A. Samples                                      C. Progressively metabolized  
B. A process of methylation                  D. None of the above
112. There is little danger in eating fish because this term is nearly non-toxic.  
A. Arsenic compound                      C. Toxic waste disposal problem  
B. Arsenic levels                              D. None of the above

### **Arsenic Environmental Issues**

#### **Arsenic Control Measures Can Affect Finished Water Quality**

113. Public water systems may need to adjust their finished water quality to address new concerns about?  
A. Corrosion                                  C. Arsenic alloys  
B. Arsenates                                  D. None of the above

114. Changes in water chemistry due to using new sources, blending different source waters, or installing arsenic treatment are some of the factors that can affect distribution system water quality. In some cases, this may cause an increase in arsenic levels in the distribution system or create simultaneous compliance issues with other drinking water regulations.  
A. True                      B. False

### **Occurrence in drinking water**

115. Parts of New England, Michigan, Wisconsin, Minnesota and the Dakotas are also known to have significant concentrations of?  
A. Arsenic in ground water                  C. Arsenic-rich particles  
B. Arsenic levels                                  D. None of the above
116. Increased levels of skin cancer have been associated with arsenic exposure in Wisconsin, even at levels below this term drinking water standard, although this link has not been proven.  
A. 100 ppb                                      C. 10 part per billion  
B. 0.4 mg/L                                      D. None of the above
117. According to a recent film funded by the US Superfund, millions of private wells have this term levels.  
A. Arsenic poisoning                          C. Blending different source waters  
B. Unknown arsenic                          D. None of the above
118. Low-level exposure to arsenic at concentrations found commonly in US drinking water compromises the initial immune response to this missing term according to NIEHS-supported scientists.  
A. Acute exposure                                  C. Acute oral exposure  
B. H1N1 or swine flu infection              D. None of the above

### Wood Preservation in the US

119. The direct or indirect ingestion of wood ash from burnt CCA lumber has caused fatalities in animals and serious poisonings in humans; the lethal human dose is approximately 20 grams of ash.

- A. True      B. False

### Water Purification Solutions

#### Small-scale water treatment

120. A simpler and less expensive form of arsenic removal is known as this term using three pitchers containing cast iron turnings and sand in the first pitcher and wood activated carbon and sand in the second.

- A. Sono arsenic filter      C. Progressively forward filter  
B. Arsenic feed      D. None of the above

121. These systems are in use and can last for years while avoiding this term disposal problem inherent to conventional arsenic removal plants.

- A. Toxic waste      C. Arsenic levels  
B. Arsenic exposure      D. None of the above

122. In the United States small "under the sink" units have been used to remove arsenic from drinking water. This option is called?

- A. Ion Exchange      C. Reverse osmosis and electro dialysis  
B. Point of use      D. None of the above

123. Which of the following and activated alumina have been considered but not commonly used?

- A. Ion exchange      C. Domestic treatment  
B. Concrete stabilization      D. None of the above

#### Arsenic Large-scale water treatment

124. The effectiveness of any method depends on the biological makeup of a particular water supply.

- A. True      B. False

125. Some large utilities with multiple water supply wells could shut down those wells with high iron concentrations, and produce only from wells or surface water sources that meet the arsenic action level

- A. True      B. False

126. The aqueous chemistry of \_\_\_\_\_ is complex, and may affect the removal rate that can be achieved by a particular process.

- A. Arsenic      C. Phosphorus acid  
B. Solid yellow arsenic      D. None of the above

127. Small utilities with only a few wells, may have no available water supply that meets the arsenic \_\_\_\_\_.

- A. Long-term column performance      C. Domestic treatment  
B. Standard      D. None of the above

128. Coagulation/filtration also known as this term removes arsenic by coprecipitation and adsorption using iron coagulants.
- A. Traditional anion exchange      C. Flocculation  
B. Domestic treatment              D. None of the above
129. Which of the following using alum is already used by some utilities to remove suspended solids and may be adjusted to remove arsenic?
- A. Traditional anion exchange      C. Coagulation/filtration  
B. Domestic treatment              D. None of the above
130. The toxic arsenic sludge are disposed of by?
- A. Activated alumina              C. Point of use  
B. Concrete stabilization      D. None of the above
131. Which of the following filters the water through a granular medium containing ferric oxide?
- A. Activated alumina              C. Point of use  
B. Iron oxide adsorption          D. None of the above
132. Which of the following eventually becomes saturated, and must be replaced?
- A. Ion Exchange                  C. Reverse osmosis and electrodialysis  
B. Iron oxide medium              D. None of the above
133. Which of the following columns connected to shallow tube wells in India and Bangladesh have successfully removed both As(III) and As(V) from groundwater for decades?
- A. Activated alumina              C. Point of use  
B. Concrete stabilization          D. None of the above
134. Which of the following performance has been possible through the efforts of community-elected water committees that collect a local water tax for funding operations?
- A. Ion Exchange                  C. Reverse osmosis and electrodialysis  
B. Long-term column              D. None of the above
135. Which of the following has long been used as a water-softening process?
- A. Ion Exchange                  C. Reverse osmosis and electrodialysis  
B. Activated alumina              D. None of the above
136. Which of the following is effective in removing As(V), but not As (III), or arsenic trioxide?
- A. Traditional anion exchange      C. One of these methods to reduce total dissolved solids  
B. Treatment trains                  D. None of the above
137. Which of the following removal of arsenic requires a trained operator to maintain the column?
- A. Traditional anion exchange              C. Ion exchange  
B. Precipitation/ coprecipitation and filtration      D. None of the above
138. Both Reverse osmosis and \_\_\_\_\_ can remove arsenic with a net ionic charge.
- A. Activated alumina              C. Point of use  
B. Electrodialysis                  D. None of the above

139. Some utilities presently use one of these methods to reduce total dissolved solids and therefore improve \_\_\_\_\_.

- A. Taste
- B. Influent and effluent concentrations
- C. Precipitation
- D. None of the above

### **Subterranean Arsenic Removal (SAR) Technology**

140. The oxidation zone created by aerated water boosts the activity of \_\_\_\_\_ which can oxidize arsenic from +3 to +5 state SAR Technology.

- A. Arsenic
- B. Arsenic alloys
- C. Arsenic-oxidizing microorganisms
- D. None of the above

141. No chemicals are used and \_\_\_\_\_ is produced during operational stage since iron and arsenic compounds are rendered inactive in the aquifer itself.

- A. Almost no sludge
- B. Solid yellow arsenic
- C. Gray arsenic
- D. None of the above

### **The Hungarian Solution**

142. Hungarian engineer László Schremmer has recently discovered that by the use of this term it is possible to reduce the arsenic content of water to 3 microgram/liter.

- A. Traditional anion exchange
- B. Influent and effluent concentrations
- C. Chaff-based filters
- D. None of the above

### **Arsenic Can Build Up on and Release in Pipes and Storage Tanks**

143. Which of the following may also find deposits of arsenic-rich particles in their storage tanks or at locations in their distribution system with low flows?

- A. Regulatory cleanup levels
- B. Storage tanks
- C. Water Systems
- D. None of the above

144. If the flow is increased or a storage tank is drawn down to a low level, these arsenic-rich particles can get stirred up and conveyed to consumers' taps.

- A. True
- B. False

145. Public water systems with arsenic in their raw water may find that scales on pipes and other components in their \_\_\_\_\_ contain relatively high arsenic concentrations.

- A. Water
- B. Meters
- C. Distribution systems
- D. None of the above

146. Because iron is so effective at binding with arsenic, corrosion deposits can have high concentrations of?

- A. Arsenic solids
- B. Arsenic alloys
- C. Aluminum arsenide
- D. None of the above

### **Who Needs to Know about Arsenic Treatment Technologies?**

147. Arsenic is a common inorganic element found broadly in the environment. It is in many industrial products, wastes, and wastewaters, and is a contaminant of concern at many remediation sites.

- A. True
- B. False



148. Arsenic contaminated \_\_\_\_\_ must be treated by removing Arsenic or immobilizing it.  
A. Arsenates            C. Soil, waste, and water  
B. Arsenic alloys       D. None of the above
149. Because arsenic readily changes valence states and reacts to form species, effective, long-term treatment of Arsenic can be simple.  
A. True            B. False
150. In some disposal environments Arsenic has leached from \_\_\_\_\_ at high concentrations.  
A. Arsenate            C. Arsenic-bearing wastes  
B. Arsenic alloys       D. None of the above
151. Drinking water suppliers may need to add new treatment processes or retrofit existing treatment systems to meet the revised?  
A. US drinking water guideline       C. Arsenic level  
B. MCL                                        D. None of the above

#### **Where Does Arsenic Come From?**

152. Industrial products having arsenic include wood preservatives, paints, environment include mining and smelting operations; agricultural applications; burning of fossil fuels and wastes; pulp and paper production; cement manufacturing; and former agricultural uses of Arsenic.  
A. True            B. False

#### **How Does Arsenic Chemistry Affect Treatment?**

153. Arsenic is a metalloid or inorganic semiconductor that can form?  
A. Valence state and chemical form       C. Inorganic and organic compounds  
B. Valence states of -3 and 0                D. None of the above
154. Which of the following of -3 and 0 occur only rarely in nature?  
A. Valence state       C. Inorganic and organic compounds  
B. Chemical form       D. None of the above
155. The toxicity and mobility of arsenic varies with its?  
A. Valence state and chemical form       C. Inorganic and organic compounds  
B. Valence states of -3 and 0                D. None of the above
156. Which of the following are the dominant species in surface water and sea water, and organic arsenic species can be found in natural gas and shale oil?  
A. Arsenate                                        C. Gray arsenic  
B. Arsenite and arsenate       D. None of the above
157. Which of the following exhibit varying degrees of toxicity and solubility?  
A. Groundwater       C. Chemical compounds containing arsenic  
B. Arsenic levels       D. None of the above

158. Arsenic readily changes this term in the environment.

- A. Valence state and chemical form
- B. Toxicity and mobility of arsenic
- C. Inorganic and organic compounds
- D. None of the above

159. Which of the following can also affect the mobility of arsenic in the environment?

- A. Long-term column performance
- B. Adsorption-desorption reactions
- C. Domestic treatment
- D. None of the above

160. The successful express treatment and long-term disposal of arsenic requires an understanding of arsenic chemistry and the disposal environment.

- A. True
- B. False

### **How Often Does Arsenic Occur in Drinking Water?**

161. Which of the following is a fairly common environmental contaminant?

- A. Arsenic
- B. Arsenates
- C. Phosphorus acid
- D. None of the above

162. The levels of arsenic are typically higher in?

- A. Arsenic exposure
- B. Sea water
- C. Groundwater sources
- D. None of the above

### **How Often Does Arsenic Occur at Hazardous Waste Sites?**

163. Hazardous waste sites fall under several clean-up programs, such as this term along with corrective actions, and state cleanup programs.

- A. EPA
- B. OSHA
- C. RCRA
- D. None of the above

### **Different Arsenic Treatment Technologies**

#### **Number of Applications of Arsenic Treatment Technologies at Superfund Sites**

164. Information on the application of groundwater pumps and treatment technologies, including precipitation/coprecipitation, this term, adsorption, and ion exchange, is based on available data and is not comprehensive.

- A. Activated alumina
- B. Membrane filtration
- C. Point of use
- D. None of the above

### **Treatment Trains**

165. Treatment trains consist of two or more technologies used together, either integrated into a single process or operated as?

- A. Traditional anion exchange
- B. Influent and effluent concentrations
- C. A series of treatments in sequence
- D. None of the above

166. A common treatment train used for arsenic in water includes an oxidation step to change arsenic from As(III) to its less soluble As(V) state, followed by this term and filtration to remove the precipitate.

- A. Treatment trains
- B. Influent and effluent concentrations
- C. Precipitation/ coprecipitation
- D. None of the above

167. Which of the following are employed when one technology alone is not capable of treating all of the contaminants?

- A. Traditional anion exchange
- B. Trains
- C. One of these methods to reduce total dissolved solids
- D. None of the above

168. Which of the following terms, where available, often were provided for the entire train, and not the individual components?

- A. Trains
- B. Influent and effluent concentrations
- C. Precipitation/ coprecipitation and filtration
- D. None of the above

169. Which of the following is most commonly used to treat organic contaminants?

- A. Activated alumina
- B. Activated carbon adsorption
- C. Point of use
- D. None of the above

### **What Technologies Are Used Most Often to Treat Arsenic?**

170. The most frequently used technology for soil and waste containing arsenic is?

- A. Solidification/stabilization
- B. Vitrification
- C. The Rust treatment technologies
- D. None of the above

171. The available data show that this technology can effectively meet regulatory cleanup levels, is commercially available to treat both soil and waste, is usually less expensive, and generates a residual that typically does not require?

- A. Iron removal treatment
- B. Vitrification
- C. Further treatment prior to disposal
- D. None of the above

172. Other arsenic treatment technologies for soil and waste are typically used for?

- A. Regulatory cleanup levels
- B. Iron removal treatment
- C. Specific applications
- D. None of the above

173. Vitrification may be used when a combination of contaminants are present that cannot be effectively treated using?

- A. Iron removal treatment
- B. Solidification/stabilization
- C. Relatively high arsenic concentrations
- D. None of the above

174. Which of the following typically requires large amounts of energy, can be more expensive than S/S, and may generate off-gasses containing arsenic?

- A. Regulatory cleanup levels
- B. Vitrification
- C. Iron removal treatment
- D. None of the above

175. Which of the following is used primarily to treat soil. It is not applicable to all types of soil or to waste?

- A. Soil washing/acid extraction
- B. Organic extraction
- C. Toxic waste extraction
- D. None of the above

176. Which of the following has been used primarily to recycle arsenic from industrial wastes containing high concentrations of arsenic from metals refining and smelting operations?

- A. Iron removal treatment
- B. Vitrification
- C. Pyrometallurgical treatment
- D. None of the above

177. \_\_\_\_\_ treats soil in place, eliminating the need to excavate soil.

- A. In situ soil flushing
- B. Clarification and filtration
- C. Lime softening
- D. None of the above

178. Which of the following is frequently used to treat arsenic contaminated water, and is capable of treating a wide range of influent concentrations to the revised MCL for arsenic?

- A. Precipitation/ coprecipitation
- B. Clarification and filtration
- C. Best available technologies (BATs)
- D. None of the above

179. The effectiveness of precipitation/ coprecipitation technology is less likely to be reduced by characteristics and contaminants other than arsenic, compared to other water treatment technologies.

- A. True
- B. False

180. Which of the following is more cost effective at a large scale where labor costs can be spread over a larger amount of treated water produced?

- A. Precipitation/ coprecipitation
- B. Lime softening
- C. Clarification and filtration
- D. None of the above

181. The effectiveness of this term for arsenic treatment is more likely than precipitation/coprecipitation to be affected by characteristics and contaminants other than arsenic.

- A. Adsorption and ion exchange
- B. Clarification and filtration
- C. Lime softening
- D. None of the above

#### **EPA Water Treatment Processes Section**

182. Treating your water to reduce arsenic will be necessary if more cost-effective alternatives are not available. EPA has identified this term and small system compliance technologies for removing arsenic from drinking water.

- A. Precipitation/ coprecipitation
- B. Clarification and filtration
- C. Best available technologies (BATs)
- D. None of the above

183. BATs are technologies that have proven effective for large systems, and this term are technologies that are effective and affordable for small systems.

- A. SSCTs
- B. Clarification and filtration
- C. Lime softening
- D. None of the above

184. Systems can use technologies not listed as \_\_\_\_\_ if they are effective.

- A. SSCTs
- B. Clarification and filtration
- C. BATs or SSCTs
- D. None of the above

185. Which of the following if approved by the State, would allow the system to supply water with an arsenic level above the MCL for a certain period of time?

- A. A general variance
- B. An exclusion
- C. An exception
- D. None of the above

186. EPA anticipates that most small systems will use this term, reverse osmosis POU devices, or modified lime softening.

- A. Clarification and filtration
- B. Activated alumina
- C. Concrete stabilization
- D. None of the above

### Activated Alumina

187. When AA is exhausted it is simply disposed of and replaced with fresh?

- A. Activated alumina(AA)
- B. Concrete stabilization
- C. Ion Exchange
- D. None of the above

### Reverse Osmosis

188. Which of the following can treat water containing up to 0.160 mg/L of arsenic?

- A. Activated alumina
- B. Reverse osmosis
- C. Electrodialysis
- D. None of the above

### Modified Lime Softening

189. The addition of lime to water causes calcium and magnesium to form solid particles, which can then be removed by?

- A. A general variance
- B. Clarification and filtration
- C. Lime softening
- D. None of the above

190. Which of the following is very expensive and water systems are unlikely to install this technology only for arsenic removal?

- A. Precipitation/ coprecipitation
- B. Clarification and filtration
- C. Lime softening
- D. None of the above

191. Which of the following can treat water containing up to 0.080 mg/L of arsenic?

- A. Modified lime softening
- B. Clarification and filtration
- C. Lime softening
- D. None of the above

### Point-of-Use Units

192. Under the Arsenic Rule, systems have this approach involves system-installed and maintained \_\_\_\_\_ on a single tap in each customer's household.

- A. Ion Exchange
- B. POU devices
- C. Concrete stabilization
- D. None of the above

193. Which of the following the EPA is developing guidance on how to implement a POU compliance strategy.

- A. Activated alumina
- B. Concrete stabilization
- C. Point-of-use reverse osmosis treatment unit
- D. None of the above

### Model of a Precipitation/Coprecipitation System

194. Which of the following has been the most frequently used method to treat arsenic contaminated water, including groundwater, surface water, leachate, mine drainage, drinking water, and wastewater?

- A. Traditional anion exchange
- B. Precipitation/coprecipitation
- C. Coagulation/filtration
- D. None of the above

195. Which of the following uses chemicals to transform dissolved contaminants into an insoluble solid?

- A. Traditional anion exchange
- B. Precipitation
- C. Coagulation/filtration
- D. None of the above

196. Colloidal or suspended contaminants become enmeshed with other precipitated species, or are removed through processes such as?

- A. Traditional anion exchange
- B. Concrete stabilization
- C. Coagulation and flocculation
- D. None of the above

197. The precipitated/coprecipitated solid is then removed from the liquid phase by?

- A. Traditional anion exchange
- B. Concrete stabilization
- C. Clarification or filtration
- D. None of the above

198. Which of the following usually involves pH adjustment and addition of a chemical precipitant or coagulant; it can also include addition of a chemical oxidant?

- A. Traditional anion exchange
- B. Precipitation/coprecipitation
- C. Coagulation/filtration
- D. None of the above

199. Oxidation of arsenic to its less soluble As(V) state can increase the effectiveness of \_\_\_\_\_, and can be done as a separate pretreatment step or as part of the precipitation process.

- A. Pretreatment
- B. Clarification or filtration
- C. Precipitation/coprecipitation
- D. None of the above

200. Which of the following that oxidize As(III) to As(V) include ozonation, photo oxidation?

- A. Pretreatment processes
- B. Clarification or filtration
- C. Precipitation/coprecipitation processes
- D. None of the above

201. Which of the following is commonly used to remove the solid precipitate. Precipitation/coprecipitation is frequently used to treat water contaminated with metals?

- A. Oxidation of arsenic
- B. Clarification or filtration
- C. An active ex situ treatment technology
- D. None of the above

202. \_\_\_\_\_ is frequently used to treat water contaminated with metals.

- A. Pretreatment processes
- B. Clarification or filtration
- C. Precipitation/coprecipitation processes
- D. None of the above

### **Precipitation/Coprecipitation Chemistry**

#### **Precipitation Reactions**

203. Which of the following occur all around us?

- A. Traditional anion exchange
- B. Precipitation reactions
- C. Coagulation/filtration
- D. None of the above

204. Another example is a kidney stone, it is nothing more than a precipitate - often of \_\_\_\_\_ ions and oxalates?

- A. Sodium
- B. Potassium
- C. Calcium
- D. None of the above

### Complex

205. The chemistry of \_\_\_\_\_ is often complex, and depends upon a variety of factors, including the speciation of arsenic, the chemical precipitants used and their concentrations.

- A. Long-term column performance
- B. Precipitation/coprecipitation
- C. Domestic treatment
- D. None of the above

### Factors Affecting Precipitation/Coprecipitation Performance

206. Valence state of arsenic - The presence of this term of arsenic may reduce the removal efficiency.

- A. Valence state and chemical form
- B. Toxicity and mobility of arsenic
- C. Soluble trivalent state
- D. None of the above

207. Which of the following depends upon its valence state, pH, the specific arsenic compound, and the presence of other chemicals with which arsenic might react?

- A. Solubility of arsenic
- B. Toxicity and mobility of arsenic
- C. Inorganic and organic compounds
- D. None of the above

208. The optimal pH range for this term depends upon the waste treated and the specific treatment process.

- A. Pretreatment processes
- B. Clarification or filtration
- C. Precipitation/coprecipitation
- D. None of the above

209. Sulfite could decrease arsenic removal in processes using ferric chloride as a coagulant, while the presence of sodium or iron may increase the removal of arsenic in these processes

- A. True
- B. False

### Applicability, Advantages, and Potential Limitations

210. Which of the following is an active ex situ treatment technology designed to function with routine chemical addition and sludge removal?

- A. Pretreatment processes
- B. Clarification or filtration
- C. Precipitation/coprecipitation
- D. None of the above

211. Some sludge from the precipitation/coprecipitation of arsenic can be a hazardous waste and require additional treatment such as this term prior to disposal.

- A. Solidification/stabilization
- B. Clarification or filtration
- C. An active ex situ treatment technology
- D. None of the above

212. In the presence of other metals or contaminants, arsenic this term may also cause other compounds to precipitate, which can render the resulting sludge hazardous.

- A. Pretreatment processes
- B. Oxidation of arsenic
- C. Precipitation/coprecipitation processes
- D. None of the above

### Factors Affecting Precipitation/Coprecipitation Costs

213. Type of chemical addition - The chemical added will affect costs. For example, calcium hypochlorite, is a less expensive oxidant than?

- A. Pretreatment processes
- B. Oxidation of arsenic
- C. Potassium permanganate
- D. None of the above

214. Chemical dosage - The cost generally increases with increased?

- A. Sludge
- B. Chemical addition
- C. Additional treatment or disposal
- D. None of the above

215. Larger amounts of chemicals added usually results in a larger amount of?

- A. Sludge
- B. Chemical addition
- C. Additional treatment or disposal
- D. None of the above

216. Treatment goal - Application could require additional treatment to meet stringent cleanup goals and/or effluent and?

- A. Remove dissolved arsenic species
- B. Additional treatment or disposal
- C. Disposal standards
- D. None of the above

217. Which of the following could be considered a hazardous waste and require additional treatment before disposal, or disposal as hazardous waste?

- A. Precipitation/coprecipitation process
- B. Effluent and disposal standards
- C. Increased chemical addition
- D. None of the above

### **Membrane Filtration for Arsenic**

218. Which of the following can remove a wide range of contaminants from water?

- A. Reverse osmosis (RO)
- B. Precipitation/coprecipitation
- C. Membrane filtration
- D. None of the above

219. Its effectiveness is sensitive to a variety of untreated water contaminants and characteristics. It also produces a larger volume of residuals and tends to be more expensive than?

- A. Reverse osmosis (RO)
- B. Precipitation/coprecipitation
- C. Other arsenic treatment technologies
- D. None of the above

220. Therefore, it is used less frequently than precipitation/coprecipitation?

- A. NF and RO
- B. The low pressure processes
- C. Adsorption and ion exchange
- D. None of the above

221. Which of the following separates contaminants from water by passing it through a semi-permeable barrier or membrane?

- A. Reverse osmosis (RO)
- B. Precipitation/coprecipitation
- C. Membrane filtration
- D. None of the above

### **Technology Description and Principles**

222. There are four types of membrane processes: this missing term, ultrafiltration (UF), nanofiltration (NF), and reverse osmosis (RO).

- A. Reverse osmosis (RO)
- B. The low pressure processes
- C. Microfiltration (MF)
- D. None of the above

223. All four of these processes are \_\_\_\_\_ and are categorized by the size of the particles that can pass through the membranes or by the molecular weight cut off of the membrane.

- A. Pressure-driven
- B. Low pressure processes
- C. Arsenic removers
- D. None of the above



224. The force required to drive fluid across the membrane depends on the pore size; NF and RO require a relatively high pressure, while this term requires lower pressure.

- A. NF and RO
- B. The low pressure processes
- C. MF and UF
- D. None of the above

225. Which of the following primarily remove contaminants through physical sieving, and the high pressure processes through chemical diffusion across the permeable membrane?

- A. Reverse osmosis (RO)
- B. The high pressure processes
- C. The low pressure
- D. None of the above

226. Because arsenic species dissolved in water tend to have relatively low molecular weights, only \_\_\_\_\_ membrane processes are likely to effectively treat dissolved arsenic.

- A. NF and RO
- B. The low pressure processes
- C. MF and UF
- D. None of the above

227. Which of the following has been used with precipitation/coprecipitation to remove solids containing arsenic?

- A. Reverse osmosis (RO)
- B. NF and RO
- C. MF
- D. None of the above

### Membrane filtration processes

228. Which of the following process is a separating process, in which a feed flow is divided into two flows, either gaseous or liquid?

- A. Oxidation
- B. High pressure processes
- C. A membrane
- D. None of the above

229. If the two phases are fluid, then we speak of?

- A. MF is a low-pressure process
- B. Membrane filtration
- C. Membrane fouling
- D. None of the above

230. The membrane itself forms a semi-permeable barrier through which some particles are transported faster than others, so that?

- A. NF occurs
- B. A separation occurs
- C. High-pressure occurs
- D. None of the above

231. The pressure driven membrane filtration processes are: microfiltration (MF), ultrafiltration (UF), nanofiltration (NF) and?

- A. Reverse osmosis (RO)
- B. Oxidation
- C. Membrane fouling
- D. None of the above

232. The smaller the pore size of the membranes, the higher the pressure needed to achieve separation. In the case of microfiltration and ultrafiltration, we speak of low-pressure processes, while this term are high-pressure processes.

- A. Oxidation
- B. RO
- C. Nanofiltration and reverse osmosis
- D. None of the above

233. Which of the following generates two treatment residuals from the influent waste stream: a treated effluent and a rejected waste stream of concentrated contaminants?

- A. Membrane fouling
- B. NF
- C. MF
- D. None of the above

234. The molecular weight cut off for this term ranges from 1 to 20,000, which is a significantly lower cut off than for NF membranes.

- A. NF membranes
- B. RO membranes
- C. High-pressure processes
- D. None of the above

235. The molecular weight cut off for these membranes ranges from approximately 150 to 20,000.

- A. Adsorption
- B. NF
- C. MF
- D. None of the above

236. NF is slightly less efficient than this term in removing dissolved arsenic from water.

- A. Reverse osmosis (RO)
- B. The low pressure processes
- C. Arsenic concentrations
- D. None of the above

### Factors Affecting Membrane Filtration Performance

237. Suspended solids, high molecular weight, dissolved solids, organic compounds, and colloids - The presence of these constituents in feed stream may cause \_\_\_\_\_.

- A. Pressure
- B. Adsorption of arsenic
- C. Membrane fouling
- D. None of the above

238. Which of the following of the influent stream to convert As(III) to As(V) will increase arsenic removal?

- A. Post oxidation
- B. Prior oxidation
- C. High-pressure processes
- D. None of the above

239. pH may affect the adsorption of arsenic on the membrane by creating?

- A. Adsorption of arsenic
- B. Mechanical force
- C. An electrostatic charge
- D. None of the above

240. Temperature - Low influent stream temperatures decreases membrane flux. Increasing system pressure or increasing the membrane surface area may compensate for?

- A. Oxidation
- B. Low influent stream temperature
- C. Precipitation/ coprecipitation
- D. None of the above

241. Which of the following is a low-pressure process that primarily removes particles with a molecular weight above 50,000 or a particle size greater than 0.050 micrometers?

- A. MF
- B. NF
- C. Membrane fouling
- D. None of the above

242. The pore size of MF membranes is too large to effectively remove dissolved arsenic species, but MF can remove particulates containing arsenic and solids produced by?

- A. Oxidation
- B. Low pressure processes
- C. Precipitation/ coprecipitation
- D. None of the above

### Media and Contaminants Treated

243. Which of the following can treat dissolved salts and other dissolved materials?

- A. Membrane filtration
- B. Additional treatment
- C. Increased chemical addition
- D. None of the above

### Adsorption Treatment for Arsenic

244. Which of the following has been used to treat groundwater and drinking water containing arsenic?

- A. Adsorption
- B. Greensand
- C. Precipitation/coprecipitation
- D. None of the Above

245. Based on the information collected for this course, this technology typically can reduce arsenic concentrations to less than \_\_\_\_\_ and in some cases has reduced arsenic concentrations to below 0.010 mg/L.

- A. 50 ppb to 10 ppb
- B. 0.050 mg/L
- C. 10 ug/L (micrograms per liter) or 10 ppb
- D. None of the above

246. It is used less frequently than \_\_\_\_\_, and is most commonly used to treat groundwater and drinking water, or as a polishing step for other water treatment processes.

- A. Adsorption
- B. Greensand
- C. Precipitation/coprecipitation
- D. None of the above

247. \_\_\_\_\_, solutes (contaminants) concentrate at the surface of a sorbent, thereby reducing their concentration in the bulk liquid phase.

- A. Adsorption
- B. Greensand
- C. Precipitation/coprecipitation
- D. None of the above

248. The adsorption media is usually packed into?

- A. Bulk liquid phase
- B. Adsorption filter
- C. A column
- D. None of the above

249. When adsorption sites become filled, the column must be regenerated or disposed of and replaced with?

- A. Bulk liquid phase
- B. Adsorption sand
- C. New media
- D. None of the above

### Technology Description and Principles

250. The primary removal mechanism in each process is adsorption. For example, greensand is made from?

- A. Glauconite
- B. Greensand
- C. Precipitation/coprecipitation
- D. None of the Above

251. Which of the following containing sand is treated with potassium permanganate, forming a layer of manganese oxides on the sand?

- A. Bulk liquid phase
- B. Glauconite
- C. Greensand media
- D. None of the above



261. Processes that use these media typically remove arsenic using adsorption in combination with oxidation, precipitation/coprecipitation?

- A. NF and RO
- B. The low pressure processes
- C. Ion exchange or filtration
- D. None of the above

262. Which of the following uses adsorption and ion exchange with surface hydroxides to selectively remove arsenic from water?

- A. Greensand media
- B. Activated carbon (AC)
- C. Iron oxide-coated sand
- D. None of the above

263. The media requires periodic regeneration or disposal and replacement with new media. The regeneration process is similar to that used for \_\_\_\_\_, and consists of rinsing the media with a regenerating solution containing excess sodium hydroxide, flushing with water, and neutralizing with a strong acid, such as sulfuric acid.

- A. AA
- B. Activated carbon (AC)
- C. The regeneration process
- D. None of the above

264. Which of the following is prepared by treating zeolite with a solution of surfactant, such as hexadecyltrimethyl-ammonium bromide?

- A. Ion exchange
- B. Greensand media
- C. SMZ
- D. None of the above

### **Zeolite**

265. The name zeolite is a general term for a stone like material that consist of this term with a large internal surface area of up to 1000 m<sup>2</sup>/g.

- A. The optimal pH
- B. Zeolite
- C. Crystalline metal-alumo-silicates
- D. None of the above

266. The word zeolite is of Greek origin and means – directly translated – ?

- A. Adsorption
- B. Boiling rock
- C. Reduction
- D. None of the above

267. More than 40 natural and 100 synthetic \_\_\_\_\_ are known.

- A. Crystal lattices
- B. Zeolites
- C. Molecular sieves
- D. None of the above

268. Even after several thousand adsorption/desorption cycles, the structural changes of this term are insignificant if the process parameters pressure and temperature do not exceed certain limits.

- A. Crystal lattice
- B. Zeolites
- C. Molecular sieves
- D. None of the above

269. The application diversity of zeolites is tremendous: they are applied as molecular sieves, as adsorbents, as catalysts in cracking of hydrocarbons in the petro-chemical industry, as filler components in paper production and as?

- A. Adsorption sponges
- B. Zeolites
- C. Ion exchange material in detergents
- D. None of the above

270. The price, e.g. for this missing term is between 1.00 and 8.00 DM/kg, depending on the type and consistency of material delivered.

- A. Adsorption
- B. Zeolites
- C. Laundry detergent zeolite
- D. None of the above

### Media and Contaminants Treated

271. Which of the following is frequently used to remove organic contaminants and metals from industrial wastewater?

- A. Adsorption
- B. Reduction
- C. Ion exchange
- D. None of the above

### Summary of Performance Data

272. Which of the following treatment effectiveness can be evaluated by comparing influent and effluent contaminant concentrations?

- A. Reduction
- B. Adsorption
- C. Iron-based adsorption media
- D. None of the above

### Factors Affecting Adsorption Performance

273. Fouling - The presence of suspended solids, organics, solids, silica, or mica, can cause fouling of this term's media.

- A. Adsorption
- B. Reduction
- C. Ion exchange
- D. None of the above

274. Arsenic oxidation state – \_\_\_\_\_ is more effective in removing As(V) than As(III).

- A. Adsorption
- B. Activated carbon (AC)
- C. Reduction
- D. None of the above

275. Flow rate - Increasing the rate of flow through this term can decrease the adsorption of contaminants.

- A. The exchange medium
- B. Influent arsenic concentration
- C. Adsorption unit
- D. None of the above

276. Wastewater pH - The optimal pH to maximize adsorption of arsenic by this term is acidic.

- A. Adsorption
- B. Activated carbon (AC)
- C. Activated alumina
- D. None of the above

277. In two groundwater and surface water projects the influent arsenic concentration was between this term, and the effluent concentration was less than 0.010 mg/L.

- A. 10 ppb
- B. 0.010 mg/L
- C. 0.010 mg/L and 0.050 mg/L
- D. None of the above

278. Of the ten drinking water projects (eight full and two pilot scale) having both influent and effluent arsenic concentration data, eight had influent concentrations greater than?

- A. 10 ppb
- B. 0.010 mg/L
- C. 0.050 mg/L
- D. None of the above

279. Effluent concentrations of less than 0.050 mg/L were achieved in seven of these projects. For two drinking water projects, the influent arsenic concentration was between this term, and the effluent concentration was less than 0.010 mg/L.

- A. 0.010 mg/L and 0.050 mg/L
- B. 0.010 mg/L
- C. 0.050 mg/L
- D. None of the above

280. Projects that did not reduce arsenic concentrations to below this term do not necessarily indicate that adsorption cannot achieve these levels.

- A. 50 ppb to 10 ppb
- B. 0.010 mg/L
- C. 0.050 or 0.010 mg/L
- D. None of the above

### **Ion Exchange Treatment for Arsenic**

281. Which of the following has been used to treat groundwater and drinking water containing arsenic?

- A. The exchange medium
- B. Post-treatment
- C. Ion exchange
- D. None of the above

282. Based on the information collected to prepare this course, this technology typically can reduce arsenic concentrations to less than this term and in some cases has reduced arsenic concentrations to below 0.010 mg/L.

- A. 10 ppb
- B. 0.010 mg/L
- C. 0.050 mg/L
- D. None of the above

283. Its effectiveness is sensitive to a variety of untreated water contaminants and characteristics. It is used less frequently than this term, and is most commonly used to treat groundwater and drinking water, or as a polishing step for other water treatment processes.

- A. The exchange medium
- B. Influent arsenic concentration
- C. Precipitation/coprecipitation
- D. None of the above

284. Ion exchange is a physical/chemical process in which ions held electrostatically on the surface of a solid are exchanged for ions of similar charge in?

- A. A solution
- B. A column
- C. More frequent bed regeneration
- D. None of the above

285. It removes ions from the aqueous phase by the exchange of cations or anions between the contaminants and?

- A. The exchange medium
- B. Influent arsenic concentration
- C. Groundwater and drinking water
- D. None of the above

### **Technology Description and Principles**

286. The medium used for this term is typically a resin made from synthetic organic materials, inorganic materials, or natural polymeric materials that contain ionic functional groups.

- A. Ion exchange
- B. Replenish the exchanged ions
- C. More frequent bed regeneration
- D. None of the above

287. Dissolved arsenic is usually in an anionic form, and weak base resins tend to be effective over this term, and strong base resins are typically used for arsenic treatment.

- A. A chloride ion
- B. Arsenic removal
- C. A smaller pH range
- D. None of the above

288. Which of the following may also be categorized by the ion that is exchanged with the one in solution?

- A. The regenerating solution
- B. A column
- C. Resins
- D. None of the above

289. Resins that exchange a chloride ion are referred to as?

- A. An anionic form
- B. Chloride-form resins
- C. The regeneration process
- D. None of the above

290. Resins that preferentially exchange sulfate ions are referred to as?

- A. Sulfate-selective
- B. A column
- C. More frequent bed regeneration
- D. None of the above

291. Both sulfate-selective and nitrate-selective resins have been used for?

- A. A column
- B. Arsenic removal
- C. The regeneration process
- D. None of the above

292. The resin is usually packed into this term, and as contaminated water is passed through the column, contaminant ions are exchanged for other ions such as chloride or hydroxide in the resin.

- A. A column
- B. Arsenic removal
- C. The regeneration process
- D. None of the above

293. Ion exchange is often preceded by treatments such as this term to remove organics, suspended solids, and other contaminants that can foul the resins and reduce their effectiveness.

- A. The regeneration process
- B. Arsenic removal
- C. Filtration and oil-water separation
- D. None of the above

294. Which of the following resins must be periodically regenerated to remove the adsorbed contaminants and replenish the exchanged ions?

- A. Ion exchange
- B. Column
- C. Bed regeneration
- D. None of the above

295. The volume of spent regeneration solution ranges from 1.5 to 10 percent of the treated water volume depending on the feed water quality and type of unit?

- A. Ion exchange
- B. Arsenic removal
- C. The regeneration process
- D. None of the above

296. The number of \_\_\_\_\_ that can be treated before regeneration is needed can range from 300 to 60,000.

- A. Ion exchange bed volumes
- B. Columns
- C. Bed regenerations
- D. None of the above

### Factors Affecting Ion Exchange Performance

297. Valence state - As(III) is generally not removed by?

- A. The regeneration process
- B. Arsenic removal
- C. Ion exchange
- D. None of the above



298. Which of the following can reduce the effectiveness of ion exchange if ions in the resin are replaced by ions other than arsenic, resulting in a need for more frequent bed regeneration?

- A. Frequent bed regeneration
- B. Exchange ion
- C. The regenerating solution
- D. None of the above

299. Fouling - The presence of organics, suspended solids, calcium, or iron, can cause this missing term of ion exchange resins.

- A. The regeneration process
- B. Arsenic removal
- C. Fouling
- D. None of the above

300. Presence of trivalent iron - The presence of Fe (III) could cause arsenic to form complexes with the iron that are not removed by?

- A. Ion exchange
- B. The regenerating solution
- C. Frequent bed regeneration
- D. None of the above

**You are finished with your Assignment.**