

**Registration form**

**DISTRIBUTION 202 \$150.00**  
**48 HOUR RUSH ORDER PROCESSING FEE ADDITIONAL \$50.00**

**Start and Finish Dates:** \_\_\_\_\_

*You will have 90 days from this date in order to complete this course*

List number of hours worked on assignment must match State Requirement. \_\_\_\_\_

**Name** \_\_\_\_\_ **Signature** \_\_\_\_\_

*I have read and understood the disclaimer notice on page 2. Digitally sign XXX*

**Address** \_\_\_\_\_

**City** \_\_\_\_\_ **State** \_\_\_\_\_ **Zip** \_\_\_\_\_

**Email** \_\_\_\_\_ **Fax (\_\_\_\_)** \_\_\_\_\_

**Phone:**  
**Home (\_\_\_\_)** \_\_\_\_\_ **Work (\_\_\_\_)** \_\_\_\_\_

**Operator ID #** \_\_\_\_\_ **Exp. Date** \_\_\_\_\_

**Class/Grade** \_\_\_\_\_

*Your certificate will be emailed to you in about two weeks.*

**Please circle/check which certification you are applying the course CEU's.**

Water Treatment  Water Distribution  Other \_\_\_\_\_

**Technical Learning College PO Box 3060, Chino Valley, AZ 86323**  
**Toll Free (866) 557-1746 Fax (928) 272-0747 [info@tlch2o.com](mailto:info@tlch2o.com)**

If you've paid on the Internet, please write your Customer# \_\_\_\_\_

Please invoice me, my PO# \_\_\_\_\_

**Please pay with your credit card on our website under Bookstore or Buy Now. Or call us and provide your credit card information.**

***We will stop mailing the certificate of completion we need your e-mail address. We will e-mail the certificate to you, if no e-mail address; we will mail it to you.***

## **DISCLAIMER NOTICE**

I understand that it is my responsibility to ensure that this CEU course is either approved or accepted in my State for CEU credit. I understand State laws and rules change on a frequent basis and I believe this course is currently accepted in my State for CEU or contact hour credit, if it is not, I will not hold Technical Learning College responsible. I fully understand that this type of study program deals with dangerous, changing conditions and various laws and that I will not hold Technical Learning College, Technical Learning Consultants, Inc. (TLC) liable in any fashion for any errors, omissions, advice, suggestions or neglect contained in this CEU education training course or for any violation or injury, death, neglect, damage or loss of your license or certification caused in any fashion by this CEU education training or course material suggestion or error or my lack of submitting paperwork. It is my responsibility to call or contact TLC if I need help or assistance and double-check to ensure my registration page and assignment has been received and graded. It is my responsibility to ensure all information is correct and to abide with all rules and regulations.

**Professional Engineers;** Most states will accept our courses for credit but we do not officially list the States or Agencies. Please check your State for approval.

*You can obtain a printed version of the course manual from TLC for an additional \$69.95 plus shipping charges.*

## **AFFIDAVIT OF EXAM COMPLETION**

I affirm that I personally completed the entire text of the course. I also affirm that I completed the exam without assistance from any outside source. I understand that it is my responsibility to file or maintain my certificate of completion as required by the state or by the designation organization.

## **Grading Information**

In order to maintain the integrity of our courses we do not distribute test scores, percentages or questions missed. Our exams are based upon pass/fail criteria with the benchmark for successful completion set at 70%. Once you pass the exam, your record will reflect a successful completion and a certificate will be issued to you.

## **Rush Grading Service**

If you need this assignment graded and the results mailed to you within a 48-hour period, prepare to pay an additional rush service handling fee of \$50.00. This fee may not cover postage costs. If you need this service, simply write RUSH on the top of your Registration Form. We will place you in the front of the grading and processing line.

For security purposes, please fax or e-mail a copy of your driver's license and always call us to confirm we've received your assignment and to confirm your identity.

**Do not solely depend on TLC's Approval list for it may be outdated.**

**All downloads are electronically tracked and monitored for security purposes.**

**Distribution 202 Answer Key**      Name \_\_\_\_\_

Phone \_\_\_\_\_

***You are solely responsible to ensure this course is accepted for credit. No refunds. Did you check with your State agency to ensure this course is accepted for credit?***

***Method of Course acceptance confirmation. Please fill this section***  
**Do not solely depend on TLC's Approval list for it may be outdated.**

**Website \_\_ Telephone Call\_\_ Email\_\_ Spoke to\_\_\_\_\_**

**Did you receive the approval number, if applicable? \_\_\_\_\_**

**What is the course approval number, if applicable? \_\_\_\_\_**

***You are responsible to ensure that TLC receives the Assignment and Registration Key. Please call us to ensure that we received it.***

**You can utilize Adobe Acrobat DC to electronically complete your assignment**

Please Circle, Bold, Underline or X, one answer per question.

- |                 |                 |                 |
|-----------------|-----------------|-----------------|
| 1. A B          | 22. A B C D E F | 43. A B C D E F |
| 2. A B          | 23. A B C D E F | 44. A B C D E F |
| 3. A B          | 24. A B C D E F | 45. A B C D E F |
| 4. A B          | 25. A B C D E F | 46. A B         |
| 5. A B          | 26. A B         | 47. A B C D E F |
| 6. A B          | 27. A B C D E F | 48. A B C D E F |
| 7. A B          | 28. A B C D E F | 49. A B C D E F |
| 8. A B          | 29. A B C D E F | 50. A B C D E F |
| 9. A B          | 30. A B C D E F | 51. A B C D E F |
| 10. A B         | 31. A B C D E F | 52. A B C D E F |
| 11. A B         | 32. A B C D E F | 53. A B C D E F |
| 12. A B         | 33. A B C D E F | 54. A B C D E F |
| 13. A B C D E F | 34. A B C D E F | 55. A B C D E F |
| 14. A B C D E F | 35. A B C D E F | 56. A B C D E F |
| 15. A B C D E F | 36. A B C D E F | 57. A B C D E F |
| 16. A B         | 37. A B C D E F | 58. A B C D E F |
| 17. A B C D E F | 38. A B C D E F | 59. A B C D E F |
| 18. A B C D E F | 39. A B C D E F | 60. A B C D E F |
| 19. A B C D E F | 40. A B C D E F | 61. A B C D E F |
| 20. A B C D E F | 41. A B C D E F | 62. A B C D E F |
| 21. A B C D E F | 42. A B C D E F | 63. A B C D E F |

64. ABCDEF  
65. ABCDEF  
66. ABCDEF  
67. ABCDEF  
68. A B  
69. ABCDEF  
70. ABCDEF  
71. ABCDEF  
72. ABCDEF  
73. ABCDEF  
74. ABCDEF  
75. A B  
76. ABCDEF  
77. ABCDEF  
78. ABCDEF  
79. ABCDEF  
80. ABCDEF  
81. ABCDEF  
82. ABCDEF  
83. A B  
84. A B  
85. ABCDEF  
86. ABCDEF  
87. ABCDEF  
88. ABCDEF  
89. A B  
90. ABCDEF  
91. A B  
92. ABCDEF  
93. A B  
94. A B  
95. A B  
96. A B  
97. A B  
98. A B  
99. ABCDEF  
100. A B  
101. ABCDEF  
102. ABCDEF  
103. ABCDEF

104. ABCDEF  
105. ABCDEF  
106. ABCDEF  
107. ABCDEF  
108. ABCDEF  
109. ABCDEF  
110. ABCDEF  
111. ABCDEF  
112. ABCDEF  
113. A B  
114. ABCDEF  
115. ABCDEF  
116. ABCDEF  
117. ABCDEF  
118. ABCDEF  
119. A B  
120. A B  
121. ABCDEF  
122. ABCDEF  
123. ABCDEF  
124. ABCDEF  
125. ABCDEF  
126. A B  
127. ABCDEF  
128. ABCDEF  
129. ABCDEF  
130. ABCDEF  
131. ABCDEF  
132. ABCDEF  
133. ABCDEF  
134. ABCDEF  
135. ABCDEF  
136. ABCDEF  
137. ABCDEF  
138. ABCDEF  
139. ABCDEF  
140. ABCDEF  
141. ABCDEF  
142. ABCDEF  
143. ABCDEF

144. ABCDEF  
145. ABCDEF  
146. A B  
147. ABCDEF  
148. ABCDEF  
149. ABCDEF  
150. ABCDEF  
151. ABCDEF  
152. A B  
153. A B  
154. A B  
155. A B  
156. ABCDEF  
157. ABCDEF  
158. ABCDEF  
159. ABCDEF  
160. ABCDEF  
161. ABCDEF  
162. ABCDEF  
163. ABCDEF  
164. A B  
165. A B  
166. ABCDEF  
167. ABCDEF  
168. A B  
169. A B  
170. ABCDEF  
171. A B  
172. ABCDEF  
173. ABCDEF  
174. ABCDEF  
175. A B  
176. A B  
177. A B  
178. ABCDEF  
179. ABCDEF  
180. ABCDEF  
181. A B  
182. A B  
183. ABCDEF

184. A B  
185. A B C D E F  
186. A B C D E F  
187. A B C D E F  
188. A B C D E F  
189. A B C D E F  
190. A B C D E F  
191. A B C D E F  
192. A B C D E F  
193. A B C D E F  
194. A B C D E F  
195. A B C D E F  
196. A B C D E F  
197. A B C D E F  
198. A B C D E F  
199. A B C D E F  
200. A B C D E F  
201. A B C D E F  
202. A B C D E F  
203. A B C D E F  
204. A B C D E F  
205. A B C D E F  
206. A B C D E F  
207. A B C D E F  
208. A B C D E F  
209. A B C D E F  
210. A B C D E F  
211. A B C D E F  
212. A B C D E F  
213. A B C D E F  
214. A B C D E F  
215. A B C D E F  
216. A B C D E F  
217. A B C D E F  
218. A B C D E F  
219. A B C D E F  
220. A B C D E F  
221. A B C D E F  
222. A B C D E F  
223. A B  
224. A B C D E F  
225. A B C D E F  
226. A B C D E F  
227. A B  
228. A B C D E F  
229. A B C D E F  
230. A B C D E F  
231. A B C D E F  
232. A B C D E F  
233. A B C D E F  
234. A B C D E F  
235. A B C D E F  
236. A B C D E F  
237. A B C D E F  
238. A B C D E F  
239. A B C D E F  
240. A B C D E F  
241. A B  
242. A B C D E F  
243. A B C D E F  
244. A B C D E F  
245. A B  
246. A B  
247. A B C D E F  
248. A B  
249. A B C D E F  
250. A B C D E F  
251. A B C D E F  
252. A B C D E F  
253. A B C D E F  
254. A B C D E F  
255. A B C D E F  
256. A B C D E F  
257. A B C D E F  
258. A B C D E F  
259. A B  
260. A B C D E F  
261. A B C D E F  
262. A B C D E F  
263. A B  
264. A B C D E F  
265. A B C D E F  
266. A B C D E F  
267. A B C D E F  
268. A B C D E F  
269. A B C D E F  
270. A B C D E F  
271. A B C D E F  
272. A B C D E F  
273. A B C D E F  
274. A B  
275. A B C D E F  
276. A B C D E F  
277. A B C D E F  
278. A B  
279. A B C D E F  
280. A B  
281. A B  
282. A B  
283. A B  
284. A B C D E F  
285. A B C D E F  
286. A B C D E F  
287. A B  
288. A B C D E F  
289. A B C D E F  
290. A B  
291. A B C D E F  
292. A B C D E F  
293. A B  
294. A B C D E F  
295. A B C D E F  
296. A B  
297. A B C D E F  
298. A B C D E F  
299. A B C D E F  
300. A B C D E F

***You are responsible to ensure that TLC receives the Assignment and Registration Key. Please call us to ensure that we received it.***

**Please fax the answer key to TLC Western Campus  
Fax (928) 272-0747  
Backup Fax (928) 468-0675**

Always call us after faxing the paperwork to ensure that we've received it.

**Additional certificate for another Agency – additional fee \$50**

**Rush Grading Service**

If you need this assignment graded and the results mailed to you within a 48-hour period, prepare to pay an additional rush service handling fee of \$50.00.

*Please e-mail or fax this survey along with your final exam*

**WATER DISTRIBUTION 202 CEU COURSE  
CUSTOMER SERVICE RESPONSE CARD**

NAME: \_\_\_\_\_

E-MAIL \_\_\_\_\_ PHONE \_\_\_\_\_

***PLEASE COMPLETE THIS FORM BY CIRCLING THE NUMBER OF THE APPROPRIATE ANSWER IN THE AREA BELOW.***

1. Please rate the difficulty of your course.

Very Easy 0 1 2 3 4 5 Very Difficult

2. Please rate the difficulty of the testing process.

Very Easy 0 1 2 3 4 5 Very Difficult

3. Please rate the subject matter on the exam to your actual field or work.

Very Similar 0 1 2 3 4 5 Very Different

4. How did you hear about this Course? \_\_\_\_\_

5. What would you do to improve the Course?

---

---

How about the price of the course?

Poor \_\_\_\_ Fair \_\_\_\_ Average \_\_\_\_ Good \_\_\_\_ Great \_\_\_\_

How was your customer service?

Poor \_\_\_\_ Fair \_\_\_\_ Average \_\_\_\_ Good \_\_\_\_ Great \_\_\_\_

Any other concerns or comments.

---

---





## Water Distribution 202 CEU Training Course Assignment

*The Assignment (Exam) is also available in Word on the Internet for your Convenience, please visit [www.ABCTLc.com](http://www.ABCTLc.com) and download the assignment and e- mail it back to TLC.*

You will have 90 days from the start of this course to complete in order to receive your Professional Development Hours (**PDHs**) or Continuing Education Unit (**CEU**). A score of 70 % is necessary to pass this course. We prefer if this exam is proctored. No intentional trick questions. If you should need any assistance, please email all concerns and the completed manual to [info@tlch2o.com](mailto:info@tlch2o.com).

We would prefer that you utilize the enclosed answer sheet in the front, but if you are unable to do so, type out your own answer key. Please include your name and address on your Answer Key and make copy for yourself. You can e-mail or fax your Answer Key along with the Registration Form to TLC. **(S) Means answer may be plural or singular. Multiple Choice Section. One answer per question and please use the answer key.**

### Water Introduction

1. Because raw water is never completely pure of pollution, we need to properly treat it. Most of the earth's water sources get their water supplies through precipitation. During precipitation, water passes over and through the ground, acquiring a wide variety of dissolved or suspended impurities that intensely alters its usefulness.

A. True      B. False

2. Water has unique physical and biological properties. These characteristics also have an indirect influence on the types of treatment methods and/or chemicals.

A. True      B. False

3. With surface water, it is important to remember that raw water will normally contain industrial pollutants and varying amounts of dissolved minerals including calcium, magnesium, sodium, chlorides, sulfates and bicarbonates, depending on its source.

A. True      B. False

4. With treated water, it is common to find traces of iron, manganese, copper, aluminum, nitrates, insecticides and herbicides.

A. True      B. False

5. Although the maximum amounts of all these substances as mentioned above, are strictly limited by the regulations (MCLS). These are usually referred to as contaminants and/or pollutants.

A. True      B. False

### Physical Characteristics of Water

6. Physical characteristics such as pH, TDS, taste, odor, temperature and turbidity; this is how the consumer judges how well the provider is treating the water.

A. True      B. False

7. Physical characteristics are the elements found are non-metals such as fluoride, sulfides or acids, alkalies and metals.

A. True      B. False

8. Total Dissolved Solids (TDS) is a primary pollutant and an indicator of aesthetic water characteristics such as hardness.

- A. True      B. False

9. pH is the negative logarithm of the hydrogen ion concentration,  $[H^+]$ , a measure of the degree to which a solution is alkaline or acidic.

- A. True      B. False

### Biological Characteristics of Water

10. Biological characteristics are the presence of living or dead organisms.

- A. True      B. False

### Radiological Characteristics

11. Radiological characteristics are the result of water coming in contact with commercial materials.

- A. True      B. False

### Topic 2- Waterborne Pathogen Section - Introduction

12. Bacteria, viruses and protozoan that cause disease are known as pathogens.

- A. True      B. False

13. Most pathogens are generally associated with diseases that \_\_\_\_\_ and affect people in a relatively short amount of time, generally a few days to two weeks.

- A. Limits the treatment process      D. Will cause fatalities  
B. Are mild in nature      E. Limit the travel of pathogens  
C. Cause intestinal illness      F. None of the Above

### How Diseases are Transmitted.

14. Waterborne pathogens are primarily spread by the?

- A. Fecal-oral, or feces-to-mouth, route      D. Influenza route  
B. Dermal to fecal route      E. Waterborne mishaps  
C. Oral to fecal route      F. None of the Above

15. When infected humans or animals pass the bacteria, viruses, and \_\_\_\_\_ in their stool, pathogens may get into water and spread disease.

- A. Fecal Coliform and E coli      D. Cryptosporidiosis  
B. Protozoa      E. Bioslime  
C. Macroorganisms      F. None of the Above

16. For another person to become infected, he or she must take the pathogen in through the mouth.

- A. True      B. False

17. Which term means that in nature, it is different from other types of pathogens such as the viruses that cause influenza (the flu) or the bacteria that cause tuberculosis?

- A. Fecal Coliform and E coli      D. Waterborne Pathogen(s)  
B. Giardia lamblia      E. Coliform bacteria  
C. Microorganism(s)      F. None of the Above

18. According to the text, \_\_\_\_\_ are spread by secretions that are coughed or sneezed into the air by an infected person.

- A. Fecal Coliform and E coli
- B. Giardia lamblia
- C. Microorganisms
- D. Influenza virus and tuberculosis bacteria
- E. Coliform bacteria
- F. None of the Above

### Topic 2- Bacteriological Monitoring Section

19. Which of the following are usually harmless, occur in high densities in their natural environment and are easily cultured in relatively simple bacteriological media?

- A. Indicator bacteria
- B. Bacteria tests
- C. Contaminate
- D. Microbiological analysis
- E. Presence of an indicator
- F. None of the Above

20. Indicators in common use today for routine monitoring of drinking water include total coliforms, fecal coliforms, and?

- A. Sample container
- B. Bacteria tests
- C. Coliform bacteria
- D. Escherichia coli (E. coli)
- E. Iron bacteria
- F. None of the Above

21. According to the text, the routine microbiological analysis of your water is for?

- A. Indicator bacteria
- B. Bacteria tests
- C. Contamination
- D. Coliform bacteria
- E. Presence of an indicator
- F. None of the Above

22. Which of the following terms is used as an indicator organism to determine the biological quality of your water?

- A. Microbiological analysis
- B. Bac-T
- C. Coliform bacteria
- D. Escherichia coli (E. coli)
- E. Presence of an indicator
- F. None of the Above

23. The presence of an indicator or \_\_\_\_\_ in your drinking water is an important health concern.

- A. Indicator bacteria
- B. Pathogenic bacteria
- C. Contaminate
- D. Microbiological analysis
- E. Presence of an indicator
- F. None of the Above

24. Which of the following terms is used to signal possible fecal contamination, and therefore, the potential presence of pathogens?

- A. Indicator bacteria
- B. Pathogenic bacteria
- C. Contaminate
- D. Microbiological analysis
- E. Presence of an indicator
- F. None of the Above

### Bacteria Sampling

25. Water samples for \_\_\_\_\_ must always be collected in a sterile container.

- A. Indicator
- B. Bacteria tests
- C. Contamination
- D. pH analysis
- E. Presence of an indicator
- F. None of the Above

26. Refrigerate the sample and transport it to the testing laboratory within eight hours (in an ice chest). Many labs will accept bacteria samples on Friday. Mailing Indicator bacteria is not recommended because laboratory analysis results are not as reliable.  
A. True      B. False

27. Which bug forms an obvious slime on the inside of pipes and fixtures? A water test is not needed for identification. Check for a reddish-brown slime inside a toilet tank or where water stands for several days.  
A. Colonies                                      D. Escherichia coli (E. coli)  
B. Algae    E. Iron bacteria  
C. Coliform bacteria                            F. None of the Above

28. Which of the following are common in the environment and are generally not harmful, but the presence of these bacteria in drinking water is usually a result of a problem with the treatment system or the pipes that distribute water, and indicates that the water may be contaminated with germs that can cause disease?  
A. Diseases                                      D. Escherichia coli (E. coli)  
B. Germs    E. Iron bacteria  
C. Coliform bacteria                            F. None of the Above

**Laboratory Procedures**

29. The laboratory may perform the \_\_\_\_\_ in one of four methods approved by the U.S. EPA and your local environmental or health division.  
A. Colilert                                      D. Total coliform analysis  
B. Coliform                                        E. Pathogen test  
C. Sample time                                F. None of the Above

**Methods**

30. The MMO-MUG test, a product marketed as \_\_\_\_\_, is the most common. The sample results will be reported by the laboratories as simply coliforms present or absent.  
A. Colilert                                      D. Total coliform analysis  
B. Coliform                                        E. Pathogen media  
C. Sample stuff                                F. None of the Above

31. If coliforms are present, the laboratory will analyze the sample further to determine if these are \_\_\_\_\_ and \_\_\_\_\_ and report their presence or absence.  
A. Colilert, E. coli                              D. Total coliform analysis, Pathogens  
B. Coliforms, E. coli                            E. Pathogens, Total coliform analysis  
C. Fecal coliforms, E. coli                    F. None of the Above

**Types of Water Samples**

32. It is important to properly identify the type of \_\_\_\_\_ you are collecting.  
A. Colilert      D. Total coliform analysis  
B. Coliforms    E. Pathogens  
C. Sample      F. None of the Above

**The three (3) types of samples are:**

33. Samples collected following a coliform present' routine sample. The number of repeat samples to be collected is based on the number of \_\_\_\_\_ samples you normally collect.

- A. Repeat
- B. Special
- C. QA QC
- D. Total coliform analysis
- E. Routine
- F. None of the Above

34. What type of samples can be collected for other reasons? Examples would be a sample collected after repairs to the system.

- A. Repeat
- B. Special
- C. Sample
- D. Total coliform analysis
- E. Routine
- F. None of the Above

35. What type of samples can be collected on a routine basis to monitor for contamination? Collection should be in accordance with an approved sampling plan.

- A. Repeat
- B. Special
- C. Sample
- D. Total coliform analysis
- E. Routine
- F. None of the Above

**Repeat Sampling**

36. Which of the following terms is total coliform or fecal coliform present, a set of repeat samples must be collected within 24 hours after being notified by the laboratory?

- A. MCL compliance
- B. Distribution system
- C. Routine sample
- D. Original sampling location
- E. Repeat sample(s)
- F. None of the Above

**The follow-up for repeat sampling is:**

37. If only one \_\_\_\_\_ per month or quarter is required, four (4) repeat samples must be collected.

- A. Special Sample
- B. Routine sample
- C. Repeat sample(s)
- D. Coliform present
- E. Original sampling location
- F. None of the Above

38. For systems collecting two (2) or more routine samples per month, three (3) \_\_\_\_\_ must be collected.

- A. Compliance sample
- B. Distribution sample
- C. Routine sample
- D. QA/QC Split
- E. Repeat sample(s)
- F. None of the Above

39. Repeat samples must be collected from: Within five (5) service connections upstream from the?

- A. MCL compliance
- B. Distribution system
- C. Routine sample
- D. Original sampling location
- E. Repeat sample(s)
- F. None of the Above

40. Repeat samples must be collected from: Within five (5) service connections downstream from the?

- A. Special Sample
- B. Routine sample
- C. Repeat sample(s)
- D. Coliform present
- E. Original sampling location
- F. None of the Above

41. Repeat samples must be collected from: If the system has only one service connection, the \_\_\_\_\_ must be collected from the same sampling location over a four-day period or on the same day.

- A. Special Sample
- B. Routine sample
- C. Repeat sample(s)
- D. Coliform present
- E. Original sampling location
- F. None of the Above

42. Repeat samples must be collected from: All \_\_\_\_\_ are included in the MCL compliance calculation.

- A. Special Sample
- B. Routine sample
- C. Repeat sample(s)
- D. Coliform present
- E. Original sampling location
- F. None of the Above

### Sampling Procedures

43. Which of the terms must be followed and all operating staff must be clear on how to follow the sampling plan?

- A. Seal individual samples
- B. Chain of custody
- C. Distribution system
- D. Sample siting plan
- E. Positive for total coliform
- F. None of the Above

44. Staff must be aware of how often sampling must be done, the \_\_\_\_\_ to be used for collecting the samples, and the proper procedures for identification, storage and transport of the samples to an approved laboratory.

- A. Multiple sources
- B. Sample siting plan
- C. Total coliform
- D. Proper procedures and sampling containers
- E. Sampling containers
- F. None of the Above

45. In addition, proper procedures must be followed for repeat sampling whenever a routine sample result is?

- A. Seal individual samples
- B. Chain of custody
- C. Distribution system
- D. Sample siting plan
- E. Positive for total coliform
- F. None of the Above

### Maximum Contaminant Levels (MCLs)

46. State and federal laws establish standards for drinking water quality. Under normal circumstances when these guidelines are being met, the water is somewhat safe to drink with little threat to human health.

- A. True
- B. False

47. EPA had developed standards which are known as maximum contaminant levels (MCL). When a particular contaminant exceeds \_\_\_\_\_ a potential health threat may occur.

- A. Coliform bacteria count
- B. MCL
- C. Standards
- D. HPC
- E. CFU
- F. None of the Above

48. Which acronym generally expresses properties of the contaminants, risk assessments and factors, short-term (acute) exposure and long-term (chronic) exposure?

- A. Coliform bacteria
- B. MCLs
- C. Standards
- D. HPC
- E. CFU
- F. None of the Above

49. When you as the operator take samples to ensure your water is in compliance with the MCL, there are two types of \_\_\_\_\_ for coliform bacteria.

- A. Coliform bacteria
- B. MCLs
- C. Standards
- D. MCL violations
- E. CFU
- F. None of the Above

50. Which of the following terms is for total coliform; the second is an acute risk to health violation characterized by the confirmed presence of fecal coliform or E. coli?

- A. Coliform bacteria
- B. MCLs
- C. Standards
- D. MCL violations
- E. CFU
- F. None of the Above

### Chain of Custody Procedures

51. Which of the following terms begins when the sample containers are obtained from the laboratory? From this point on, a chain of custody record will accompany the sample containers.

- A. Multiple sources
- B. Sample siting plan
- C. Total coliform
- D. Chain of custody record
- E. Sampling containers
- F. None of the Above

52. Each custody sample requires a \_\_\_\_\_ record and may require a seal. If you do not seal individual samples, then seal the containers in which the samples are shipped.

- A. Seal individual samples
- B. Chain of custody
- C. Distribution system
- D. Sample siting plan
- E. Positive for total coliform
- F. None of the Above

53. Because a sample is physical evidence, \_\_\_\_\_ procedures are used to maintain and document sample possession from the time the sample is collected until it is introduced as evidence.

- A. Multiple sources
- B. Sample siting plan
- C. Total coliform
- D. TCR
- E. Chain of custody
- F. None of the Above

54. If both parties involved in the transfer must sign, date and note the time on the chain of custody record, this is known as?

- A. Multiple sources
- B. Sample siting plan
- C. Total coliform
- D. Samples transfer possession
- E. Sampling containers
- F. None of the Above

55. The recipient will then attach the \_\_\_\_\_ showing the transfer dates and times to the custody sheets. If the samples are split and sent to more than one laboratory, prepare a separate chain of custody record for each sample.

- A. Seal individual samples
- B. Chain of custody
- C. Shipping invoices
- D. Sample siting plan
- E. Positive for total coliform
- F. None of the Above

56. If the samples are delivered to after-hours night drop-off boxes, the custody record should note such \_\_\_\_\_ and be locked with the sealed samples inside sealed boxes.

- A. Multiple sources
- B. Sample siting plan
- C. Total coliform
- D. TCR
- E. A transfer
- F. None of the Above

### Positive or Coliform Present Results

57. According to the text, if you are notified of a positive test result you need to contact either the Drinking Water Program or your local county health department within 24 hours, or by the next business day after the?

- A. Results are reported to you
- B. Positive violation
- C. Repeat sampling immediately
- D. Sample violation
- E. MCL compliance violation
- F. None of the Above

58. Ideally speaking, your Drinking Water Program Agency should contract with health departments to provide \_\_\_\_\_ to water systems.

- A. Assistance
- B. Harassment
- C. Hostility
- D. Sample help
- E. Compliance calculation
- F. None of the Above

59. Hopefully after you have contacted an agency for assistance, you will be instructed as to the proper repeat sampling procedures and possible corrective measures for solving the problem. It is very important to initiate the \_\_\_\_\_ as the corrective measures will be based on those results.

- A. Storage and distribution
- B. Repeat sampling immediately
- C. Upgrading of the wellhead area
- D. Perform routine procedures
- E. Corrective measures
- F. None of the Above

### Heterotrophic Plate Count HPC

60. Heterotrophic Plate Count (HPC) --- formerly known as the Standard Plate Count, is a procedure for estimating the number of live heterotrophic bacteria and measuring changes during water treatment and distribution in water or in swimming pools.

- A. True
- B. False

61. Colonies may arise from pairs, chains, clusters, or single cells, all of which are included in the term?

- A. Coliform bacteria units
- B. MCLs units
- C. Standards
- D. HPC units
- E. Colony-forming units
- F. None of the Above

### Spread Plate Method

62. During this method, colonies are on the \_\_\_\_\_ where they can be distinguished readily from particles and bubbles.

- A. Agar surface
- B. Surface growth area
- C. Top
- D. Bottom
- E. Material
- F. None of the Above

63. During the Spread Plate Method, colonies can be transferred quickly, and \_\_\_\_\_ easily can be discerned and compared to published descriptions.

- A. Colonies grow
- B. Surface growth
- C. Low counts
- D. Heterotrophic organisms will grow
- E. Colony morphology
- F. None of the Above



### Membrane Filter Method

64. Which method permits testing large volumes of \_\_\_\_\_ and is the method of choice for low-count waters?
- A. Colonies
  - B. Surface water
  - C. Low-turbidity water
  - D. Heterotrophic organisms
  - E. MCL
  - F. None of the Above

### Heterotrophic Plate Count (Spread Plate Method)

65. Which of the following terms use inorganic carbon sources, this is in contrast to heterotrophic organisms utilize organic compounds as their carbon source?
- A. Colonies
  - B. Surface growth
  - C. AGAR
  - D. Heterotrophic organisms
  - E. Autotrophic organisms
  - F. None of the Above

66. Which of the following terms provides a technique to quantify the bacteriological activity of a sample?
- A. Colonies
  - B. Heat
  - C. Agar
  - D. Heterotrophic Plate Count
  - E. MCL
  - F. None of the Above

67. The R2A agar provides a medium that will support a large variety of?
- A. Colonies
  - B. Bugs
  - C. Germs
  - D. Heterotrophic bacteria
  - E. MCL
  - F. None of the Above

### Total Coliforms

68. This MCL is based on the presence of total coliforms, and compliance is on a daily or weekly basis, depending on your water system type and state rule.
- A. True
  - B. False

69. For systems that collect fewer than \_\_\_\_\_ samples per month, no more than one sample per month may be positive. In other words, the second positive result (repeat or routine) in a month or quarter results in a MCL violation.
- A. 5
  - B. 10
  - C. 100
  - D. 200
  - E. 40
  - F. None of the Above

70. For systems that collect \_\_\_\_\_ or more samples per month, no more than five (5) percent may be Positive?
- A. 5
  - B. 10
  - C. 100
  - D. 200
  - E. 40
  - F. None of the Above

### Acute Risk to Health (Fecal coliforms and E. coli)

71. A(n) \_\_\_\_\_ to human health violation occurs if either one of the following happens?
- A. Routine analysis
  - B. Drinking violation
  - C. Acute risk
  - D. Human health violation
  - E. Fecal coliform or E. coli is present
  - F. None of the Above

72. A routine analysis shows total coliform present and is followed by a repeat analysis that indicates \_\_\_\_\_.

- A. Routine analysis
- B. Drinking violation
- C. Water penalty
- D. Human health violation
- E. Fecal coliform or E. coli present
- F. None of the Above

73. A routine analysis shows total and \_\_\_\_\_ is followed by a repeat analysis that indicates total coliform present.

- A. Routine analysis
- B. Drinking water violation
- C. MCL violation
- D. Human health violations
- E. Fecal coliform or E. coli present
- F. None of the Above

74. Which of the following terms requires the water system to provide public notice via radio and television stations in the area?

- A. Routine analysis violation
- B. Drinking water rule violation
- C. MCL violation
- D. Human health violation
- E. Acute health risk violation
- F. None of the Above

75. According to the text, the type of contamination can pose an immediate threat to human health and notice must be given as soon as possible, but no later than 24 hours after notification from your laboratory of the test results.

- A. True
- B. False

**The following are acute violations:**

76. Which is violation of nitrate?

- A. Presence
- B. MCL
- C. MCLG
- D. Count
- E. Acute violations
- F. None of the Above

77. Concerning total coliforms - when fecal coliforms or E. coli are present in the distribution system and is a violation of the?

- A. Presence
- B. MCL
- C. MCLG
- D. Count
- E. Acute violations
- F. None of the Above

**Topic 8- Chlorine Section**

78. What is the term that best describes the amount of chlorine needed to react with contamination species and it must be satisfied before active HOCl is available to provide a free chlorine residual?

- A. Chlorine demand
- B. HOCl
- C. High chlorine concentration
- D. Total residual
- E. The hypochlorite ion (OCI-)
- F. None of the Above

**Pathophysiology**

79. As far as chlorine safety and respiratory protection, the intermediate \_\_\_\_\_ of chlorine accounts for its effect on the upper airway and the lower respiratory tract.

- A. Generation of free oxygen radicals
- B. Vapor from Chlorine gas
- C. Effects of Hydrochloric acid
- D. Water solubility
- E. The odor threshold for chlorine
- F. None of the Above

80. According to the text, respiratory exposure to \_\_\_\_\_ may be prolonged because its moderate water solubility may not cause upper airway symptoms for several minutes.

- A. Hydrochloric acid
- B. Chlorine gas
- C. The gas
- D. The chemical species produced
- E. Plasma exudation
- F. None of the Above

81. Because chlorine gas is so dangerous, the odor threshold for chlorine is approximately?

- A. 1 parts per million (ppm)
- B. 3 parts per million (ppm)
- C. 10 parts per million (ppm)
- D. 3-5 parts per million (ppm)
- E. 0.3-0.5 parts per million (ppm)
- F. None of the Above

### Mechanism of Activity

82. The mechanisms of cellular injury are believed to result from the oxidation of functional groups in cell components, from reactions with tissue water to form \_\_\_\_\_, and from the generation of free oxygen radicals.

- A. Generation of free oxygen radicals
- B. Chlorine acid
- C. Hydrochloric acid
- D. A caustic effect
- E. Hypochlorous and hydrochloric acid
- F. None of the Above

83. Chlorine gas feeds out of the cylinder through a gas regulator. The cylinders are on a scale that operators use to measure the amount used each day. The chains are used to prevent the tanks from falling over.

- A. True
- B. False

84. Chlorine gas should be stored in vented rooms that have panic bar equipped doors.

- A. True
- B. False

### Solubility Effects

85. Which of the following terms is highly soluble in water?

- A. Hydrochloric acid
- B. H<sub>2</sub>SO<sub>4</sub>
- C. Hypochloric acid
- D. Sodium hypochlorite solution
- E. Sulfuric Acid
- F. None of the Above

86. Because it is highly water soluble, Hypochlorous acid has an injury pattern similar to?

- A. Hydrochloric acid
- B. H<sub>2</sub>SO<sub>4</sub>
- C. Hypochloric acid
- D. Sodium hypochlorite solution
- E. Sulfuric Acid
- F. None of the Above

87. Which of the following terms may account for the toxicity of elemental chlorine and hydrochloric acid to the human body?

- A. Hydrochloric acid
- B. H<sub>2</sub>SO<sub>4</sub>
- C. Hypochloric acid
- D. Hypochlorous acid
- E. Sulfuric Acid
- F. None of the Above

### Early Response to Chlorine Gas

88. If you mix ammonia with chlorine gas, this compound reacts to form?

- A. Hypochlorous acid
- B. Chlorine gas
- C. Hydrochloric acid
- D. Sulfuric acid
- E. Chloramine gas
- F. None of the Above

89. The early response to the odor threshold for chlorine depends on the (1) concentration of chlorine gas, (2) duration of exposure, (3) water content of the tissues exposed, and (4) individual susceptibility.  
A. True      B. False

### Immediate Effects

90. Which of the following answers is the best choice for the immediate effects of this substance's toxicity include acute inflammation of the conjunctivae, nose, pharynx, larynx, trachea, and bronchi?  
A. Hydrochloric acid      D. Sulfuric acid  
B. Chlorine gas      E. HOCL  
C. Hypochlorous gas      F. None of the Above

### Pathological Findings

91. Chlorine is a highly reactive gas.  
A. True      B. False

92. According to the text, treatment plants use \_\_\_\_\_ to reduce water levels of microorganisms that can spread disease to humans.  
A. HCl      D. Chlorine  
B. HOCl      E. The hypochlorite ion (OCI-)  
C. High chlorine concentrations      F. None of the Above

93. Chlorine gas is greenish yellow in color and very toxic. It is heavier than air and will therefore sink to the ground if released from its container. It is the toxic effect of Chlorine gas that makes it a good disinfectant, but it is toxic to more than just waterborne pathogens; it is also toxic to humans. It is a respiratory irritant and it can also irritate skin and mucus membranes.  
A. True      B. False

94. Chlorine gas is sold as a compressed liquid, which is amber in color. Chlorine, as a solid, is heavier (less dense) than water. If the chlorine liquid is released from its container, it will quickly return back to its liquid state.  
A. True      B. False

95. Chlorine gas is the most expensive form of chlorine to use. The typical amount of chlorine gas required for water treatment is 1-16 mg/L of water. Different amounts of chlorine gas are used depending on the quality of water that needs to be treated. If the water quality is good, a higher concentration of chlorine gas will be required to disinfect the water if the contact time cannot be increased.  
A. True      B. False

### Exposure

96. People are exposed to sodium hypochlorite by inhalation of aerosols. This causes coughing and a sore throat. After swallowing sodium hypochlorite, the effects are stomach ache, a burning sensation, coughing, diarrhea, a sore throat and vomiting. Sodium hypochlorite on skin or eyes causes redness and pain.  
A. True      B. False
97. After prolonged exposure, the skin can become sensitive. Sodium hypochlorite is poisonous for water organisms. It is mutagenic and very toxic when it comes in contact with Ammonium salts.  
A. True      B. False

### Chemistry of Chlorination

98. The hypochlorite ion is a much weaker disinfecting agent than Hypochlorous acid, about 100 times less effective.

- A. True      B. False

99. According to the text, pH and temperature affect the ratio of hypochlorous acid to hypochlorite ions. As the temperature is decreased, the \_\_\_\_\_ increases.

- A. Reduction Ratio      D. "CT" disinfection concept  
B. CT actual      E. Ratio of hypochlorous acid  
C. Free chlorine residual      F. None of the Above

100. Under normal water conditions, hypochlorous acid will also chemically react and break down into the hypochlorite ion.

- A. True      B. False

101. Temperature plays a small part in the acid ratio. Although the ratio of \_\_\_\_\_ is greater at lower temperatures, pathogenic organisms are actually harder to kill.

- A. Hypochlorous acid      D. Total chlorine  
B. The amount of chlorine      E. pH value and temperature  
C. Chlorine Demand      F. None of the Above

102. If all other things were equal, \_\_\_\_\_ and a lower pH are more conducive to chlorine disinfection.

- A. Lower pH      D. Lower water temperature  
B. Hypochlorous acid      E. The hypochlorite ion  
C. Higher water temperatures      F. None of the Above

### Types of Residual

103. \_\_\_\_\_ is all chlorine that is available for disinfection.

- A. Chlorine residual      D. Break-point chlorination  
B. Chlorine demand      E. Total chlorine  
C. Free chlorine      F. None of the Above

104. Total chlorine residual = free + \_\_\_\_\_.

- A. Chlorine residual      D. Combined chlorine residual  
B. Chlorine demand      E. Total chlorine residual  
C. Free chlorine      F. None of the Above

105. In water, there are always other substances (interfering agents) such as iron, manganese, turbidity, etc., which will combine chemically with the chlorine, these substances are called the?

- A. Chlorine residual      D. Break-point chlorination  
B. Chlorine demand      E. Total chlorine residual  
C. Pathogen reduction      F. None of the Above

106. According to the text, once chlorine molecules are combined with these interfering agents, they are not capable of disinfection. \_\_\_\_\_ is much more effective as a disinfecting agent.

- A. Chlorine residual      D. Break-point chlorination  
B. Chlorine demand      E. Total chlorine residual  
C. Free chlorine      F. None of the Above

107. Either a total or a \_\_\_\_\_ can be read when a chlorine residual test is taken,  
A. Chlorine residual                      D. Break-point chlorination  
B. Chlorine demand                      E. Total chlorine residual  
C. Free chlorine residual              F. None of the Above

108. Which of the following terms is a much stronger disinfecting agent, therefore, most water regulating agencies will require that your daily chlorine residual readings be of free chlorine residual?  
A. Free chlorine                      D. "CT" disinfection concept  
B. Total residual                      E. T10 of the process unit  
C. Free chlorine residual              F. None of the Above

109. \_\_\_\_\_ is where the chlorine demand has been satisfied, and any additional chlorine will be considered free chlorine.  
A. Chlorine residual    D. Break-point chlorination  
B. Chlorine demand    E. Total chlorine residual  
C. Free chlorine        F. None of the Above

**Residual Concentration/Contact Time (CT) Requirements**

110. Since monitoring for very low levels of pathogens in treated water is analytically very difficult, utilizing the \_\_\_\_\_ is recommended to demonstrate satisfactory treatment.  
A. Free chlorine                      D. "CT" disinfection concept  
B. Total residual                      E. T10 of the process unit  
C. Free chlorine residual              F. None of the Above

111. \_\_\_\_\_ = Concentration (mg/L) x Time (minutes)  
A. CT                                      D. Total chlorine  
B. The amount of chlorine        E. pH value and temperature  
C. Chlorine Demand                  F. None of the Above

112. The effective reduction in pathogens can be calculated by reference to standard tables of required?  
A. Free chlorine                      D. "CT" s  
B. Total residual                      E. T10 of the process unit  
C. Free chlorine residual              F. None of the Above

113. The CT concept as developed by the United States Environmental Protection Agency (uses the combination of disinfectant residual concentration (mg/L) and the effective disinfection contact time (in minutes) to measure effective pathogen reduction.  
A. True                      B. False

**Calculation and Reporting of CT Data**

114. Reduction Ratio should be reported, along with the appropriate pH, temperature, and?  
A. Reduction Ratio                      D. Disinfectant residual  
B. CT actual                              E. T10 of the process unit  
C. Free chlorine residual              F. None of the Above

### Chlorine (DDBP)

115. While testing chlorine disinfection process, you will need to understand one especially important feature is the ease of overdosing to create a "\_\_\_\_\_ " concentration.

- A. Free available chlorine and Total
- B. Residual
- C. Break point and Free
- D. Free available chlorine and Combined Chlorine
- E. Combined chlorine and readily available
- F. None of the Above

116. According to the text, this type of chlorine residual concentration residuals from 0.1 to 0.5 ppm.

- A. Free available chlorine and Total
- B. Residual
- C. Break point and Free
- D. Free available
- E. Combined chlorine and readily available
- F. None of the Above

117. A typical chlorine residual is 2 ppm for this type of chlorine residual?

- A. Free available chlorine and Total
- B. Residual
- C. Break point and Free
- D. Combined Chlorine
- E. Readily available
- F. None of the Above

### Chlorine By-Products

118. The most common chlorination by-products found in U.S. drinking water supplies are?

- A. Chlorate and Chlorite
- B. CO<sub>2</sub> and H<sub>2</sub>SO<sub>4</sub>
- C. Trihalomethanes (THMs)
- D. Ammonia and THMS
- E. Chloramines
- F. None of the Above

### The Principal Trihalomethanes are:

119. Chloroform, bromodichloromethane, chlorodibromomethane, and bromoform. Other less common chlorination by-products include the haloacetic acids and haloacetonitriles. The amount of THMs formed in drinking water can be influenced by a number of factors, including the season and the source of the water.

- A. True
- B. False

120. THM concentrations are generally higher in winter than in summer, because concentrations of natural organic matter are greater and more chlorine is required to disinfect at colder temperatures.

- A. True
- B. False

### Risks and Benefits of Chlorine

121. Many cities utilize the use of ozone to disinfect their source water and to reduce formation of this parameter?

- A. Chlorate and Chlorite
- B. CO<sub>2</sub> and H<sub>2</sub>SO<sub>4</sub>
- C. Trihalomethanes (THMs)
- D. Ammonia and THMS
- E. Chloramines
- F. None of the Above

122. \_\_\_\_\_ is a highly effective disinfectant; it breaks down quickly, so that small amounts of \_\_\_\_\_ or other disinfectants must be added to the water to ensure continued disinfection as the water is piped to the consumer's tap.

- A. Ozone, Chlorine
- B. UV, Chlorine
- C. Chlorite, Chlorine
- D. Chlorine Dioxide, Chlorine
- E. Chloramines, Chlorine
- F. None of the Above

123. Modifying water treatment facilities to use \_\_\_\_\_ can be expensive, and \_\_\_\_\_ treatment can create other undesirable by-products that may be harmful to health if they are not controlled (e.g., bromate).

- A. Ozone
- B. UV
- C. Chlorite
- D. Chlorine Dioxide
- E. Chloramines
- F. None of the Above

124. Which term is a weaker disinfectant than chlorine, especially against viruses and protozoa; however, they are very persistent and, as such, can be useful for preventing re-growth of microbial pathogens in drinking water distribution systems?

- A. Ozone
- B. UV
- C. Chlorite
- D. Chlorine Dioxide
- E. Chloramines
- F. None of the Above

125. Chlorine dioxide can be an effective disinfectant, but it forms?

- A. Chlorate and Chlorite
- B. CO<sub>2</sub> and H<sub>2</sub>SO<sub>4</sub>
- C. THMS
- D. Ammonia and THMS
- E. Chloramines
- F. None of the Above

126. It is extremely important that water treatment plants ensure that methods used to control chlorination by-products do not compromise the effectiveness of water disinfection.

- A. True
- B. False

### Ozone

127. Which compound is obtained by passing a flow of air or oxygen between two electrodes that are subjected to an alternating current in the order of 10,000 to 20,000 volts?

- A. Chloramine
- B. Liquid Ozone
- C. Ozone
- D. Oxygen and nascent oxygen
- E. O<sub>2</sub>
- F. None of the Above

128. Which compound is a light blue gas at room temperature?

- A. Chloramine
- B. Liquid Ozone
- C. Ozone
- D. Oxygen and nascent oxygen
- E. O<sub>2</sub>
- F. None of the Above

129. Ozone has a \_\_\_\_\_ similar to that sometimes noticed during and after heavy electrical storms. In use, ozone breaks down into oxygen and nascent oxygen.

- A. Self-policing pungent odor
- B. THMs
- C. Light blue gas
- D. Oxygen and nascent oxygen
- E. Strongest oxidizing agent
- F. None of the Above

130. Ozone does not form chloramines or \_\_\_\_\_, and while it may destroy some THMs, it may produce others when followed by chlorination.

- A. Carcinogens
- B. THMs
- C. Complete disinfectant
- D. Oxygen and nascent oxygen
- E. Flocculation and coagulation
- F. None of the Above



131. Ozone falls into the same category as other disinfectants in that it can produce\_\_\_\_\_.

- A. Carcinogens
- B. THMs
- C. DBPs
- D. Oxygen and nascent oxygen
- E. Strongest oxidizing agent
- F. None of the Above

132. Which compound is very unstable and can readily explode, as a result, it is not shipped and must be manufactured on-site?

- A. Chloramine
- B. Liquid Ozone
- C. Ozone
- D. Oxygen and nascent oxygen
- E. O<sub>2</sub>
- F. None of the Above

133. Each water has its own\_\_\_\_\_, in the order of 0.5 ppm to 5.0 ppm. Contact time, temperature, and pH of the water are factors to be determined.

- A. Carcinogens
- B. THMs
- C. Ozone demand
- D. Oxygen and nascent oxygen
- E. Strongest oxidizing agent
- F. None of the Above

### **Alternate Disinfectants Section Summary**

#### **Chloramines**

134. Which compound is a very weak disinfectant for Giardia and virus reduction? It is recommended that it be used in conjunction with a stronger disinfectant. It is best utilized as a stable distribution system disinfectant.

- A. Chlorine
- B. Chloramine
- C. Ozone
- D. Oxygen and nascent oxygen
- E. Strongest oxidizing agent
- F. None of the Above

135. In the production of chloramines, the ammonia residuals in the finished water, when fed in excess of stoichiometric amount needed, should be limited to inhibit growth of?

- A. Cryptosporidium
- B. Chlorine-based disinfectants
- C. Giardia lamblia
- D. An emerging parasitic protozoan pathogen
- E. Nitrifying bacteria
- F. None of the Above

#### **Chlorine Dioxide**

136. Chlorine dioxide may be used for either taste and odor control or as?

- A. Post disinfectant
- B. ClO<sub>2</sub>/chlorite/chlorate
- C. An oxidant
- D. Total residual oxidants
- E. A pre-disinfectant
- F. None of the Above

### **Topic 3 -Water Distribution Section- System Elements**

137. Distribution mains function is to carry water from the water source or treatment works to users, these are the pipelines that make up the?

- A. Increase water pressure
- B. Distribution tree
- C. Complete gridiron system
- D. Distribution system
- E. Arterial system
- F. None of the Above

138. Arterial mains are interconnected with smaller distribution mains to form a complete gridiron system and are mains for?

- A. Increasing water pressure
- B. Tree system
- C. Complete gridiron system
- D. Distribution mains of large size
- E. Fire protection
- F. None of the Above

139. Storage reservoirs are structures used to store water and \_\_\_\_\_ the supply or pressure in the distribution system.

- A. Increase water pressure
- B. Equalize
- C. Complete gridiron system
- D. Main line isolation
- E. Provide a reserve pressure
- F. None of the Above

140. Booster stations are used to \_\_\_\_\_ from storage tanks for low-pressure mains.

- A. Increase water pressure
- B. Equalize
- C. Complete gridiron system
- D. Boost flow
- E. Provide a reserve pressure
- F. None of the Above

141. Valves control the flow of water in the distribution system by isolating areas for repair or by?

- A. Increase water pressure
- B. Bypasses
- C. Complete gridiron system
- D. Main line isolation
- E. Regulating system flow or pressure.
- F. None of the Above

142. According to the text, gate valves should be used in the \_\_\_\_\_ for main line isolation.

- A. Increase water pressure
- B. Distribution tree
- C. Complete gridiron system
- D. Distribution system
- E. Arterial system
- F. None of the Above

### Butterfly Valve

143. Butterfly valves are rotary type of valves usually found on large transmission lines, and may also have an additional valve beside it known as a \_\_\_\_\_ to prevent water hammer.

- A. Regulator
- B. Bypass
- C. Complete gridiron system
- D. Main line isolation
- E. PRV
- F. None of the Above

### Water Distribution Valves

144. One purpose of installing shutoff valves in water mains at various locations within the distribution system is to allow sections of the system to be \_\_\_\_\_ or provide maintenance without significantly curtailing service over large areas.

- A. Feeders as practical
- B. Adjust the pressure
- C. Open or close the valve
- D. Curtail the service
- E. Taken out of service for repairs
- F. None of the Above

145. According to the text, at intersections of distribution mains, the number of valves required is normally one less than the number of?

- A. Ties
- B. Depends
- C. Radiating mains
- D. Throttling purposes
- E. Standardizes
- F. None of the Above

146. All buried small- and medium-sized valves should be installed in the sidewalk.

- A. True
- B. False

147. For large shutoff valves, it may be necessary to surround the valve operator or entire valve within a vault or manhole to allow?

- A. Principally
- B. Dependability
- C. Repair or replacement
- D. Minimum flow restriction
- E. Stops or allows
- F. None of the Above

### Gate Valves

148. In the distribution system, gate valves are used when a straight-line flow of fluid and?

- A. Principally
- B. Dependability
- C. Repair or replacement
- D. Minimum flow restriction
- E. Stops or allows
- F. None of the Above

149. In the distribution system, or on a residential job, gate valves are so-named because the part that either \_\_\_\_\_ flow through the valve acts somewhat like a gate.

- A. Fully drawn up
- B. Dependability
- C. Repair or replacement
- D. Minimum flow restriction
- E. Stops or allows
- F. None of the Above

150. If the valve is wide open, the gate is \_\_\_\_\_ into the valve bonnet.

- A. Fully drawn up
- B. Dependable
- C. Repair or replacement
- D. Minimum flow restriction
- E. Stops or allows
- F. None of the Above

151. Gate valves are not suitable for?

- A. Copper lines
- B. Dependability
- C. PRV
- D. Throttling purposes
- E. Pressure drops
- F. None of the Above

152. The control of flow is easy because of the valve's design, and the flow of fluid

- A. True
- B. False

### Ball Valves

153. Most ball valves require only a 180-degree turn to either completely open or close the valve.

- A. True
- B. False

154. According to the text, some ball valves are operated by planetary gears.

- A. True
- B. False

155. Ball valves should be either fully-on or fully-off, some ball valves also contain a swing check located within the ball to give the valve a check valve feature.

- A. True
- B. False

### Valve Exercising

156. Valve exercising should be done to locate inoperable due to freezing or build-up of rust or corrosion and done once per year to detect \_\_\_\_\_ and to prevent valves from becoming

- A. Malfunctioning valves
- B. Dependability
- C. Repair or replacement
- D. Minimum flow restriction
- E. Stops or allows
- F. None of the Above

157. A valve inspection should include drawing valve location maps to show distances to the \_\_\_\_\_ from specific reference.

- A. Valve(s)
- B. Stonelines
- C. Monument
- D. House
- E. Telephone pole
- F. None of the Above

158. Service connections are used to \_\_\_\_\_ or other plumbing systems to the distribution system mains.

- A. Be isolated
- B. Connect individual buildings
- C. By laying out
- D. Limits the expansion
- E. Decreases in size
- F. None of the Above

**If Excessive Torque is Needed to Work the Valve**

159. One cause of a valve failing to open are variations in the temperature and/or pressure of the?

- A. High pressure side
- B. Working fluid
- C. Closing torque applied
- D. Valve sealing surfaces
- E. Length of exposure
- F. None of the Above

160. Depending on the seat and wedge material, \_\_\_\_\_ and closing torque applied, thermal binding can also occur in high temperature situations.

- A. High pressure side
- B. Working fluid
- C. Closing torque applied
- D. Valve sealing surfaces
- E. Length of exposure
- F. None of the Above

161. Over-pressurization is when a valve can \_\_\_\_\_ when high pressure enters the cavity and has no way to escape.

- A. Over-pressurization
- B. Positive pressure differential
- C. Lock in the closed position
- D. Lock in the open position
- E. Break
- F. None of the Above

162. According to the text, a single direction sealing gate valve has a nameplate on the side of the valve that has a relief hole or pressure equalizer.

- A. True
- B. False

163. Tuberculation corrosion is caused by chemical changes produced by?

- A. Closed position
- B. Hard water
- C. Chemical changes
- D. Electricity or electrolysis
- E. Positive pressure differential
- F. None of the Above

164. Corrosion will increase the C-Factor and the carrying capacity in a pipe.

- A. True
- B. False

**System Layouts- Tree System**

165. Newer water systems are frequently expanded with planning and developed into a tree-like system.

- A. True
- B. False

166. The Tree system consists of a single main that \_\_\_\_\_ as it leaves the source and progresses through the area originally served.

- A. Be isolated
- B. Connect individual buildings
- C. By laying out
- D. Limits the expansion
- E. Decreases in size
- F. None of the Above

167. Smaller pipelines \_\_\_\_\_ the main and divide again, much like the trunk and branches of a tree.

- A. Branch off
- B. Are manifolded to
- C. Connect
- D. Limit the expansion
- E. Decrease
- F. None of the Above

168. According to the text, there are several advantages gained by laying out water mains in a loop or grid, with feeder and distributor mains interconnecting at roadway intersections and other regular intervals.

- A. True
- B. False

### Friction Loss

169. The damaged section can be isolated and the remainder of the system will still carry pressure, water will not be distributed if a single section fails.

- A. True
- B. False

170. During periods of peak fire flow demand, there will be less impact from \_\_\_\_\_ in water mains as the velocity within any given section of main.

- A. Carrying capacity
- B. Friction loss
- C. Pressure
- D. Static pressure
- E. Total pressure
- F. None of the Above

### Types of Pipes Used in the Water Distribution Field

#### Plastic Pipe (PVC)

171. Plastic pipe has seen extensive use available in different lengths and sizes; it is lighter than steel or copper and requires no special tools to install.

- A. True
- B. False

172. Plastic pipe has complete resistance to corrosion; and, in addition, it can be installed aboveground or below ground. Has several advantages over metal pipe: it is flexible; it has superior resistance to?

- A. Ease of installation
- B. An excellent combination
- C. Chemical resistance
- D. Rupture from freezing
- E. Complete resistance to corrosion
- F. None of the Above

173. PVC pipes are made of tough, strong thermoplastic material that has \_\_\_\_\_ of physical and chemical properties.

- A. Ease of installation
- B. An excellent combination
- C. Chemical resistance
- D. Array
- E. Complete resistance to corrosion
- F. None of the Above

174. PVC's chemical resistance and \_\_\_\_\_ make it an excellent material for application in various mechanical systems.

- A. Ease of installation
- B. Greater resistance
- C. Chemical resistance
- D. Design strength
- E. Complete resistance to corrosion
- F. None of the Above

#### Cast Iron (CIP)

175. CIP can be found in diameters from 3" to 48".

- A. True
- B. False

176. Advantages of CIP are its long life, ability to withstand shock loads and to withstand working pressures up to 120 psi.

- A. True      B. False

**Ductile Iron Pipe (DIP)**

177. DIP can be purchased in 4" to 45" diameters and lengths of 18' to 20'.

- A. True      B. False

178. DIP was developed to \_\_\_\_\_ associated with cast iron pipe.

- A. Overcome the breakage problems      D. Provide a High C Factor  
B. Withstand shock loads                      E. Be nearly indestructible  
C. Extend the life                                  F. None of the Above

179. DIP's main advantage is that it is \_\_\_\_\_ by internal or external pressures.

- A. Overcome the breakage problems      D. Provide a High C Factor  
B. Withstand shock loads                      E. Nearly indestructible  
C. Extend the life                                  F. None of the Above

180. DIP is sometimes protected from highly corrosive soils by wrapping the pipe in plastic sheeting prior to installation, this practice can greatly \_\_\_\_\_ of this type of pipe.

- A. Overcome the breakage problems      D. Provide a High C Factor  
B. Withstand shock loads                      E. Be nearly indestructible  
C. Extend the life                                  F. None of the Above

**Steel Pipe**

181. Steel pipe is available in various diameters and in 20' or 21' lengths; its main advantage is the ability to form it into a variety of shapes.

- A. True      B. False

182. Steel pipe's advantage is that it is able withstand corrosion by both soil and water.

- A. True      B. False

183. Steel pipe is usually galvanized or dipped in coal-tar enamel and wrapped with coal-tar impregnated felt to reduce?

- A. Corrosion problems      D. Good yielding  
B. Bending                                  E. Confusion with other pipes  
C. Costs    F. None of the Above

184. From a health standpoint coal-tar products are undergoing scrutiny and it is recommended that the appropriate regulatory agencies be contacted prior to use of this material.

- A. True      B. False

**Topic 7- Excavation and Trenching Chapter**

185. Anyone who has done excavation work will tell you that once the first bucket of dirt is out of the ground, you never know what surprises await. Tales of unmarked utilities, unexpected rock and other nightmares are common. The greatest variable, however, is the type of excavation or trenching will be done and how to protect yourself for a cave-in.

- A. True      B. False

186. Which of the following terms was revised because excavating is the most dangerous of all construction operations?

- A. Competent Rule
- B. OSHA excavation standard
- C. Inspections
- D. Protective equipment, trench conditions standard
- E. Emergency rule
- F. None of the Above

187. The second reason that OSHA revised the \_\_\_\_\_ was to clarify the requirements.

- A. Competent person
- B. Existing standard
- C. Inspections
- D. Protective equipment, trench conditions
- E. Emergency contact methods
- F. None of the Above

188. The new standard uses performance criteria that provides employers with options when classifying soil and when selecting methods to protect the \_\_\_\_\_ from cave-ins.

- A. Competent person
- B. Employee
- C. Inspections
- D. Protective equipment, trench conditions
- E. Emergency
- F. None of the Above

189. Although the standard has been clarified and \_\_\_\_\_ have options when meeting some of the requirements, employers must realize that the employee must be protected at all times.

- A. Competent person
- B. Everyone
- C. Inspections
- D. Protective equipment, trench conditions
- E. Employers
- F. None of the Above

### Competent Person

190. Which of the following terms means one who is capable of identifying existing hazards in the surroundings or working conditions which are unsanitary, hazardous, or dangerous to employees and has authorization to take prompt corrective measures to eliminate them?

- A. Competent person
- B. Everyone
- C. Inspection inspector
- D. Watchman
- E. Authorized person
- F. None of the Above

191. Which of the following terms for the purpose of this standard, one must have specific training in and be knowledgeable about soils analysis, the use of protective systems and the requirements of 29 CFR Part 1926.650-652 Subpart P.

- A. Competent person
- B. Everyone
- C. Inspection inspector
- D. Watchman
- E. Authorized person
- F. None of the Above

192. Which of the following terms are essential. Everyone is required to practice once a year. Yes, once a year.

- A. Competent person
- B. Rescue training exercises
- C. Inspections
- D. Protective equipment
- E. Emergency
- F. None of the Above

### Competent Person Duties

193. Performs daily inspections of the \_\_\_\_\_ and adjacent areas.

- A. Competent person
- B. Everyone
- C. Inspections
- D. Protective equipment and trench conditions
- E. Emergency contact methods
- F. None of the Above

194. Which of the following terms shall be made prior to the start of work and as needed throughout the shift?

- A. Competent person
- B. Examinations
- C. Inspections
- D. Protective equipment
- E. Emergency contact methods
- F. None of the Above

195. Which of the following terms shall be made after every rainstorm or other hazard occurrence?

- A. Competent person
- B. Examinations
- C. Inspections
- D. Protective equipment
- E. Emergency contact methods
- F. None of the Above

196. Knowledge of \_\_\_\_\_, telephone or radio dispatch.

- A. Competent person
- B. Everything
- C. Inspections
- D. Protective equipment, trench conditions
- E. Emergency contact methods
- F. None of the Above

197. Removes employees and \_\_\_\_\_ from hazardous conditions and makes all changes necessary to ensure their safety.

- A. Competent person
- B. All other personnel
- C. Inspections
- D. Protective equipment, trench conditions
- E. Emergency contact methods
- F. None of the Above

198. Which of the following terms – have to have proper protective equipment, hard-hats, reflective vests, steel-toed boots, harnesses, eye protection, hearing protection and drinking water?

- A. Competent person
- B. Everyone
- C. Inspections
- D. All employees
- E. Emergency contact methods
- F. None of the Above

### Scope of Work

199. During excavation work a competent person shall be on the job site at all times when personnel are working within or around the?

- A. Competent person
- B. Employees
- C. Inspections
- D. Ladder(s)
- E. Excavation
- F. None of the Above

200. Which of the following safety terms reasonably may be expected to be encountered during excavation work, shall be determined prior to opening an excavation?

- A. Competent person
- B. Employees
- C. Inspections
- D. Any other underground installation
- E. Excavation work
- F. None of the Above

201. Which of the following safety terms shall be taken to protect employees working in excavations, against the hazards posed by water accumulation?

- A. Competent person
- B. Adequate precautions
- C. Inspections
- D. Ladder(s)
- E. Excavation work
- F. None of the Above



202. A stairway, ladder, or ramp shall be used as a \_\_\_\_\_ in trench excavations that are four (4') feet or more in depth.

- A. Competent person
- B. Means of access or egress
- C. Inspections
- D. Ladder(s)
- E. Excavation work
- F. None of the Above

**Excavation Protection Systems**

203. The three basic protective systems for excavations and trenches are?

- A. Table
- B. Tabulated data
- C. Trench excavation
- D. Protective systems
- E. Sloping and benching systems, shoring, and shields
- F. None of the Above

204. Every employee in an excavation shall be protected from \_\_\_\_\_ by an adequate protective system.

- A. Table
- B. Tabulated data
- C. Trench excavation
- D. Protective systems
- E. Cave-ins
- F. None of the Above

**Sloping and Benching Systems**

205. There are four options for?

- A. Sloping
- B. Tabulated data
- C. Trench excavation
- D. Protective systems
- E. Cave-ins
- F. None of the Above

206. The table provided in \_\_\_\_\_ of the standard may be used to determine the maximum allowable angle.

- A. Appendix B
- B. Tabulated data
- C. Trench excavation data
- D. Protective system Appendix
- E. Soil section
- F. None of the Above

207. Which of the following safety terms may be prepared by a registered professional engineer can be utilized?

- A. Table
- B. Tabulated data
- C. Trench excavation
- D. Protective systems
- E. Cave-ins
- F. None of the Above

208. A registered professional engineer can design a \_\_\_\_\_ for a specific job.

- A. Table
- B. Sloping plan
- C. Trench excavation
- D. Protective systems
- E. Cave-ins
- F. None of the Above

**Shoring Systems**

209. Which of the following safety terms utilizes a framework of vertical members, horizontal members, and cross braces to support the sides of the excavation?

- A. Shoring
- B. Tabulated data
- C. Trench excavation
- D. Protective systems
- E. Cave-ins
- F. None of the Above

### Excavation Safety Plan

210. An excavation safety plan is required in written form. This plan is to be developed to the level necessary to insure complete compliance with the \_\_\_\_\_ and state and local safety standards.

- A. An excavation safety plan
- B. Adequate measures
- C. Protective systems
- D. Simplified Soil Classification Systems
- E. OSHA Excavation Safety Standard
- F. None of the Above

### Soil Classification and Identification

211. The OSHA Standards define soil classifications consist of four categories: \_\_\_\_\_, Type A, Type B, and Type C.

- A. Type A
- B. Soil classifications
- C. Competent person
- D. Trench or excavation
- E. Stable rock
- F. None of the Above

### Topic 4- Backflow/Cross-Connection Section - What is backflow? Reverse flow condition

212. Backflow is the undesirable reversal of flow of nonpotable water or other substances through a \_\_\_\_\_ and into the piping of a public water system or consumer's potable water system.

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

213. Which of the following terms can result from an increase in downstream pressure, a reduction in the potable water supply pressure, or a combination of both?

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

214. Which of the following terms can have two forms-backpressure and backsiphonage?

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

215. The principal types of mechanical backflow preventers are the reduced-pressure principle assembly, the \_\_\_\_\_, and the double check valve assembly.

- A. High hazard installations
- B. Air gap
- C. Vacuum breaker
- D. Backflow
- E. Device or method
- F. None of the Above

216. Which of the following terms can occur when there is a stoppage of water supply due to nearby firefighting, a break in a water main?

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

217. Which of the following terms is a type of backflow caused by a downstream pressure that is greater than the upstream or supply pressure in a public water system or consumer's potable water system?

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

218. Which of the following terms is the means or mechanism to prevent backflow?

- A. High hazard installations
- B. Air gap
- C. Backflow preventer
- D. Backflow
- E. Device or method
- F. None of the Above

219. According to the text, basic means of preventing backflow is an \_\_\_\_\_, which either eliminates a cross-connection or provides a barrier to backflow.

- A. High hazard installations
- B. Air gap
- C. Backflow preventer
- D. Backflow
- E. Device or method
- F. None of the Above

220. Which of the following terms is any temporary or permanent connection between a public water system or consumer's potable water system and any source or system containing nonpotable water or other substances?

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

221. Which of the following terms is a form of backflow caused by a negative pressure (i.e., a vacuum or partial vacuum) in a public water system or consumer's potable water system?

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

### **Types of Backflow Prevention Methods and Assemblies**

222. Which of the following terms must either be physically disconnected or have an approved backflow prevention device installed to protect the public water system?

- A. Backflow
- B. Backpressure
- C. Backsiphonage
- D. Cross-connection
- E. Indirect connection
- F. None of the Above

223. The type of device selected for a particular installation depends on several factors.

- A. True
- B. False

224. When the airflow is restricted, such as the case of an air gap located near a wall, the \_\_\_\_\_ separation must be increased.

- A. Open receiving vessel
- B. Backflow preventer
- C. Barrier to backflow
- D. Air gap
- E. Air break
- F. None of the Above

225. An air gap is a physical disconnection between the free flowing discharge end of a potable water pipeline and the top of an?

- A. Open receiving vessel
- B. Backflow preventer
- C. Barrier to backflow
- D. Air gap
- E. Air break
- F. None of the Above

226. Which of the following terms must be at least two times the diameter of the supply pipe and not less than one inch?

- A. Open receiving vessel
- B. Backflow preventer
- C. Barrier to backflow
- D. Air gap
- E. Air break
- F. None of the Above

227. According to the text, an air break is a physical separation between the free flowing discharge end of a potable water supply pipeline, and the overflow rim of an open or non-pressure receiving vessel.

- A. True
- B. False

228. According to the text, air gap separations must be vertically orientated a distance of at least twice the inside diameter of the supply, but never less than?

- A. 1 inch
- B. 2 inches
- C. 3 inches
- D. Backflow
- E. Depends
- F. None of the Above

229. An obstruction around or near an \_\_\_\_\_ may restrict the flow of air into the outlet pipe and nullify the effectiveness of the air gap to prevent backsiphonage.

- A. High hazard installations
- B. Backflow preventer
- C. Barrier to backflow
- D. Air gap
- E. Air break
- F. None of the Above

230. An air gap is acceptable for \_\_\_\_\_ and is theoretically the most effective protection.

- A. High hazard installations
- B. Backflow preventer
- C. Barrier to backflow
- D. Low pollutional hazards
- E. High pollutional concerns
- F. None of the Above

## **Topic 5- Groundwater Production and Treatment System**

### **Groundwater and Wells**

231. According to the text, toxic material spilled or dumped near a well can leach into which of the following terms and contaminate the groundwater drawn from that well?

- A. Unconfined aquifer(s)
- B. Groundwater
- C. Water table
- D. Well(s)
- E. Aquifer
- F. None of the Above

### **Contaminated Wells**

232. Which of the following terms can be tested to see what chemicals may be in the well and if they are present in dangerous quantities?

- A. Wells
- B. Drinking water
- C. Water table
- D. Soil moisture
- E. Karst
- F. None of the Above

233. Groundwater is withdrawn from wells to provide water when water is pumped from the ground, which of the following terms change in response to this withdrawal?

- A. Dynamics of groundwater flow
- B. Groundwater
- C. Water table
- D. Well(s)
- E. Aquifer
- F. None of the Above

234. Which of the following terms flows slowly through water-bearing formations at different rates?

- A. Well
- B. Drinking water
- C. Water table
- D. Soil moisture
- E. Groundwater
- F. None of the Above

### **Aquifer**

235. Many terms are used to describe the nature and extent of the groundwater resource, the level below which all the spaces are filled with water is called the?

- A. Unconfined aquifer(s)
- B. Groundwater
- C. Water table
- D. Well(s)
- E. Aquifer
- F. None of the Above

236. Above the water table lies the?

- A. Unsaturated zone
- B. Drinking water
- C. Water table
- D. Soil moisture
- E. Karst
- F. None of the Above

237. The entire region below the water table is called the saturated zone and water in this saturated zone is called?

- A. Unconfined aquifer(s)
- B. Groundwater
- C. Water table
- D. Well(s)
- E. Aquifer
- F. None of the Above

238. \_\_\_\_\_ are cracks, joints, or fractures in solid rock, through which groundwater moves.

- A. Fractured aquifer(s)
- B. Drinking water
- C. Water table
- D. Soil moisture
- E. Karst
- F. None of the Above

239. Limestone is often located in which of the following terms?

- A. Unconfined aquifer(s)
- B. Groundwater
- C. Water table
- D. Fractured aquifer(s)
- E. Aquifer
- F. None of the Above

240. Which of the following terms such as sandstone may become so highly cemented or recrystallized that all of the original space is filled, in this case, the rock is no longer a porous medium?

- A. Unconfined aquifer(s)
- B. Groundwater
- C. Porous media
- D. Fractured aquifer(s)
- E. Aquifer
- F. None of the Above

241. Clay has many spaces between its grains, but the spaces are not large enough to permit free movement of water.

- A. True
- B. False

242. Which of the following terms usually flows downhill with the slope of the water table?

- A. Well
- B. Drinking water
- C. Water table
- D. Soil moisture
- E. Groundwater
- F. None of the Above

243. Which of the following terms flow in the aquifers underlying springs or surface drainage basins, and does not always mirror the flow of water on the surface?

- A. Well
- B. Drinking water
- C. Water table
- D. Soil moisture
- E. Groundwater
- F. None of the Above

244. Which of the following terms may move in different directions below the ground than the water flowing on the surface?

- A. Well
- B. Drinking water
- C. Water table
- D. Soil moisture
- E. Groundwater
- F. None of the Above

245. Unconfined aquifers are those that are bounded by the water table. Some aquifers lie beneath layers of impermeable materials.

- A. True
- B. False

246. A well in such an aquifer is called an artesian well.

- A. True
- B. False

247. Which of the following terms is the level to which the water in an artesian aquifer will rise?

- A. Unconfined aquifer(s)
- B. Piezometric surface
- C. Water table
- D. Well(s)
- E. Aquifer
- F. None of the Above

### **Cone of Depression**

248. When pumping begins, water begins to flow towards the well in contrast to the natural direction of groundwater movement.

- A. True
- B. False

249. The water level in the well falls below the water table in the?

- A. Water table
- B. Groundwater
- C. Surrounding aquifer
- D. Cone of depression
- E. Well
- F. None of the Above

250. The movement of water from which term into a well results in the formation of a cone of depression?

- A. Confined aquifer
- B. An aquifer
- C. Hydrologic cycle
- D. Water table
- E. Unconfined aquifer
- F. None of the Above

251. Which of the following terms describes a three-dimensional inverted cone surrounding the well that represents the volume of water removed as a result of pumping?

- A. Water table
- B. Groundwater
- C. Gravity
- D. Cone of depression
- E. Well
- F. None of the Above

252. Which of the following terms is the vertical drop in the height between the water level in the well prior to pumping and the water level in the well during pumping?

- A. Water table
- B. Groundwater
- C. Drawdown
- D. Cone of depression
- E. Well
- F. None of the Above

253. When a well is installed in this missing term, water moves from the aquifer into the well through small holes or slits in the well casing or, in some types of wells, through the open bottom of the well?

- A. Confined aquifer
- B. Aquifer(s)
- C. Hydrologic cycle
- D. Water table
- E. An unconfined aquifer
- F. None of the Above

### Where Is Ground Water Stored?

254. Areas where ground water exists in sufficient quantities to supply wells or springs are called aquifers, a term that literally means?

- A. Water table
- B. Groundwater
- C. Water bearer
- D. Cone of depression
- E. Well
- F. None of the Above

255. Which of the following terms store water in the spaces between particles of sand, gravel, soil, and rock as well as cracks, pores, and channels in relatively solid rocks?

- A. Confined aquifer
- B. Aquifer(s)
- C. Hydrologic cycle
- D. Water table
- E. Unconfined aquifer
- F. None of the Above

256. Which of the following terms is controlled largely by its porosity, or the relative amount of open space present to hold water?

- A. Water table
- B. Groundwater
- C. An aquifer's storage capacity
- D. Cone of depression
- E. Well
- F. None of the Above

257. There are two kinds of aquifers: confined and unconfined.

- A. True
- B. False

258. If the aquifer is sandwiched between layers of relatively impermeable materials, it is called?

- A. Confined aquifer
- B. Aquifer(s)
- C. Hydrologic cycle
- D. Water table
- E. Unconfined aquifer
- F. None of the Above

259. Confined aquifers are not sandwiched between layers of relatively impermeable materials, and their upper boundaries are generally closer to the surface of the land.

- A. True
- B. False

260. Which of the following terms are frequently found at greater depths than unconfined aquifers?

- A. Confined aquifer(s)
- B. Aquifer(s)
- C. Hydrologic cycle
- D. Water table
- E. Unconfined aquifer
- F. None of the Above

### Does Ground Water Move?

261. Ground water can move sideways as well as up or down. This movement is in response to gravity, differences in elevation, and?

- A. Synthetic organic chemical(s)
- B. Differences in pressure
- C. Permeable zones
- D. Ground-water contamination
- E. Septic tanks, cesspools, and privies
- F. None of the Above

262. Ground water can move even more rapidly in karst aquifers, which are areas in which missing term and similar rocks where fractures or cracks have been widened by the action of the ground water to form sinkholes, tunnels, or even caves?

- A. Contaminant(s)
- B. Saturated zone
- C. Karst aquifer(s)
- D. Water soluble limestone
- E. Serious contamination source(s)
- F. None of the Above

### Ground-Water Quality

263. The layers of soil and particles of sand, gravel, crushed rocks, and larger rocks were thought to act as filters, trapping contaminants before they could reach the ground water.

- A. True
- B. False

264. We know that some contaminants can pass through all of these filtering layers into which term to contaminate ground water?

- A. Contaminant(s)
- B. Saturated zone
- C. Karst aquifer(s)
- D. Saturated zone
- E. Water table
- F. None of the Above

### How Does Ground Water Become Contaminated?

265. Groundwater contamination can originate on the surface of the ground, in the ground above the water table, or in the ground below the?

- A. Synthetic organic chemical(s)
- B. Ground water
- C. Permeable zones
- D. Ground-water contamination
- E. Water table
- F. None of the Above

266. If the contaminant is introduced directly into the area below \_\_\_\_\_, the primary process that can affect the impact of the contaminant is dilution by the surrounding ground water.

- A. Contaminant(s)
- B. Saturated zone
- C. Karst aquifer(s)
- D. Saturated zone
- E. Water table
- F. None of the Above

### What Kinds of Substances Can Contaminate Groundwater, and Where Do They Come from?

267. Substances that can contaminate this missing term can be divided into two basic categories: substances that occur naturally and substances produced or introduced by man's activities.

- A. Synthetic organic chemical(s)
- B. Ground water
- C. Permeable zones
- D. Ground-water contamination
- E. Septic tanks, cesspools, and privies
- F. None of the Above

268. A significant number of today's ground-water contamination problems stem from man's activities and can be introduced into ground water from?

- A. Contaminant(s)
- B. Saturated zone
- C. A variety of sources
- D. Iron, calcium, and selenium
- E. Serious contamination source(s)
- F. None of the Above



**Topic 6- Pump, Motor and Hydraulic Section**  
**Hydraulic Principles Section**

269. Hydraulics can be divided into two areas, \_\_\_\_\_ and hydrokinetics.

- A. Fluids
- B. Hydrostatics
- C. Hydrokinetics
- D. Mechanical properties of water
- E. Flow
- F. None of the Above

270. Which of the following terms includes the study of liquids in motion, is concerned with such matters as friction and turbulence generated in pipes by flowing liquids?

- A. Pressure
- B. Hydrostatics
- C. Hydrokinetics
- D. Hydraulics
- E. Flow
- F. None of the Above

271. Which of the following terms is about pressures exerted by a fluid at rest?

- A. Pressure
- B. Hydrostatics
- C. Hydrokinetics
- D. Hydraulics
- E. Flow
- F. None of the Above

272. \_\_\_\_\_ is an excellent example of deductive mathematical physics, and in which the predictions agree closely with experiment.

- A. Pressure
- B. Hydrostatics
- C. Hydrokinetics
- D. Hydraulics
- E. Flow
- F. None of the Above

273. Which of the following terms can be stated that a fluid is a substance that cannot resist a shearing stress, so that pressures are normal to confining surfaces?

- A. Pressure
- B. Hydrostatics
- C. Hydrokinetics
- D. Hydraulics
- E. Flow
- F. None of the Above

274. According to the text, hydraulics may be the physical property that varies over the largest numerical range, competing with electrical resistivity.

- A. True
- B. False

275. Which of the following terms includes the behavior of all liquids, although it is primarily concerned with the motion of liquids.

- A. Fluids
- B. Hydrostatics
- C. Hydrokinetics
- D. Hydraulics
- E. Flow
- F. None of the Above

276. \_\_\_\_\_ includes the manner in which liquids act in tanks and pipes, deals with their properties, and explores ways to take advantage of these properties.

- A. Pressure
- B. Hydrostatics
- C. Hydrokinetics
- D. Hydraulics
- E. Flow
- F. None of the Above

277. Which of the following terms includes the consideration of liquids at rest, involves problems of buoyancy and flotation?

- A. Pressure
- B. Hydrostatics
- C. Hydrokinetics
- D. Hydraulics
- E. Flow
- F. None of the Above

**Barometric Loop**

278. According to the text, the barometric loop, will provide protection against backsiphonage, is based upon the principle that a water column, at sea level pressure, will not rise above 33.9 feet. In general, barometric loops are locally fabricated, and are 35 feet high.

- A. True
- B. False

279. Which of the following terms could be measured an absolute scale, pounds per square inch absolute (psia), or gauge scale, (psiag).

- A. Static pressure
- B. Pressure
- C. Gauge pressure
- D. Sea level
- E. Atmospheric pressure
- F. None of the Above

280. Absolute pressure is equal to gauge pressure plus the atmospheric pressure.

- A. True
- B. False

281. The barometric loop consists of a continuous section of supply piping that abruptly rises to a height of approximately 233 feet and then returns back down to the originating level.

- A. True
- B. False

282. The barometric loop is a loop in the piping system that effectively protects against backpressure.

- A. True
- B. False

283. The barometric loop may not be used to protect against backsiphonage.

- A. True
- B. False

284. According to the text, absolute pressure and gauge pressure?

- A. Are the same
- B. Referred to using pressure
- C. Are related
- D. That effectively protects
- E. Permanent forces tangential
- F. None of the Above

285. Which of the following terms at sea level is 14.7 psai?

- A. Static pressure
- B. Pressure
- C. Gauge pressure
- D. Sea level
- E. Atmospheric pressure
- F. None of the Above

286. Which of the following terms is the total pressure?

- A. Static pressure
- B. Absolute pressure
- C. Gauge pressure
- D. Sea level
- E. Atmospheric pressure
- F. None of the Above

287. Gauge pressure is simply the pressure read on the gauge. If there is no pressure on the gauge other than atmospheric, the gauge will read zero.

- A. True
- B. False

### Pump Categories

288. The key to understanding a pumps operation is that a pump is to move water and generate the \_\_\_\_\_ we call pressure.

- A. Centrifugal pump(s)
- B. Impeller blade(s)
- C. Delivery force
- D. Diaphragm pump(s)
- E. Cylindrical pump housing
- F. None of the Above

289. Pump operation like with a centrifugal pump — pressure is not referred to in pounds per square inch but rather as the equivalent in elevation, is called?

- A. Inward force
- B. Head
- C. Viscous drag pump
- D. Center of the impeller
- E. Incompressible fluid
- F. None of the Above

290. According to the text, pumps may be classified based on the application they serve.

- A. True
- B. False

291. According to the text, all pumps may be divided into two major categories: (1) dynamic and (2)?

- A. Centrifugal
- B. Impeller
- C. Displacement
- D. Diaphragm
- E. Rotary
- F. None of the Above

### Basic Water Pump

292. According to the text, the centrifugal pumps work by spinning water around in a circle inside a?

- A. Vortex
- B. Cylinder
- C. Viscous drag pump
- D. Center of the impeller
- E. Cylindrical pump housing
- F. None of the Above

293. The pump makes the water spin by pulling it with an impeller.

- A. True
- B. False

294. In the operation of the pump, the water at the edge of the \_\_\_\_\_ inward on the water between the impeller blades and makes it possible for that water to travel in a circle.

- A. Inward force
- B. Pump pushes
- C. Viscous drag pump
- D. Center of the impeller
- E. Incompressible fluid
- F. None of the Above

295. In the operation of the pump, when water is actively flowing through the pump, arriving through a hole near the center of the impeller and leaving through a \_\_\_\_\_ near the outer edge of the pump housing, the pressure rise between center and edge of the pump is not as large.

- A. Centrifugal pump(s)
- B. Impeller blade(s)
- C. Hole
- D. Diaphragm pump(s)
- E. Cylindrical pump housing
- F. None of the Above

### Types of Water Pumps

296. The water production well industry almost exclusively uses Turbine pumps, which are a type of centrifugal pump.

- A. True
- B. False

297. Which of the following terms are variable displacement pumps that are by far used the most?

- A. Axial flow
- B. Submersible
- C. Rotary pump
- D. Turbine pump(s)
- E. Centrifugal pumps
- F. None of the Above

298. According to the text, column pipe sections can be threaded or coupled together while the drive shaft is coupled and suspended within the column by?

- A. Oil tube
- B. Spider bearings
- C. Column pipe
- D. Single or multiple bowls
- E. Pump's lifting capacity
- F. None of the Above

299. Some vertical turbines are lubricated by oil rather than water. These pumps are essentially the same as \_\_\_\_\_; only the drive shaft is enclosed within an oil tube.

- A. Oil tube
- B. Water lubricated units
- C. Column pipe
- D. Single or multiple bowls
- E. Pump's lifting capacity
- F. None of the Above

300. \_\_\_\_\_ water flowing back down the column, turning the impellers in a reverse direction.

- A. Vapor bubbles are created
- B. Chamber pressure
- C. Drive shaft is off
- D. Volumetric positive displacement is turned off
- E. Line shaft turbine is turned off
- F. None of the Above